

12-5435

(Bid #12-121)

EFM SUBMISSION NO.: 2012 EFM 071

PRESENTED: 9-21-12

ADOPTED: 9-25-12

BY THE EMERGENCY FINANCIAL MANAGER:

RESOLUTION TO PROFESSIONAL PUMP, INC. FOR PROGRESSIVE CAVITY PUMP AT
THE WATER POLLUTION CONTROL FACILITIES

BY THE EMERGENCY MANAGER


RESOLUTION

The Department of Purchases & Supplies has solicited bids for a progressive cavity pump as requested by the Utilities Department/Water Pollution Control Facilities; and


Professional Pump, Inc., 41300 Coca Cola Dr., Belleview, Michigan was the sole responsive bidder from three solicitations for said requirements. The funding for this purchase will come from the following account number: 590-550.300-977.000; and

IT IS RESOLVED, that the Department of Purchases & Supplies, upon the Emergency Financial Manager's approval, is hereby authorized to issue a purchase order to Professional Pump, Inc. for a progressive cavity pump at the Water Pollution Control Facilities in the amount not to exceed \$63,500.00. (Sewer Fund)

APPROVED-PURCHASING DEPT:


Derrick F. Jones, Purchasing Manager

APPROVED AS TO FINANCE:


Gerald Ambrose, Finance Director

APPROVED AS TO FORM:


Peter M. Bade, City Attorney


Michael K. Brown, City Administrator

EFM DISPOSITION:

ENACT ☒

REFER TO COUNCIL ☐

FAIL ☐


Edward J. Kurtz, Emergency Financial Manager

DATED: 9-25-12

9/18/12 - BDB

RESOLUTION STAFF REVIEW

August 27, 2012

Agenda Item Title: Progressive Cavity Pump for WPC

Prepared By: Robert J. Case, WPC Supervisor

Background/Summary of Proposed Action:

WPC relies on two sludge progressive cavity pumps to convey the sludge into one of its four incinerators.

The current sludge pumps are leaky, worn, unreliable, and do not convey adequate amount of sludge. WPC must have reliable sludge pumps capable of pumping six wet tons per hour to ensure that the solids treatment process continues to operate. Without a replacement pump WPC would no longer be able to dispose of the sewage solids, resulting in possible fines and penalties for permit violations, and increased operational and maintenance costs to respond to an emergency condition.

The new sludge progressive cavity pump is guaranteed to meet WPC's need for capacity and reliability. If the City is not satisfied that the equipment performs adequately, it can return the equipment at the end of a two month trial period and owe nothing.

Financial Implications:

Please issue a purchase order in the approved FY2013 budgeted amount of \$65,300.00 using account 590-550.300-977.000.

Budgeted Expenditure: Yes ☒ No ☐ Please explain if no:


Account No.: 590-550.300-977.000 - \$65,300.00

Pre-encumbered: Yes ☒ No ☐ Requisition: 1201233

Other Implications (i.e., collective bargaining): None

Staff Recommendation: Approve

Staff Person:


(Division Head or Approved Staff)

Department Approval:

