

(Purchasing No. 11000232)

EM SUBMISSION NO.: 2012EM187

PRESENTED: 3/30/12

ADOPTED: 4-3-12

BY THE EMERGENCY MANAGER

RESOLUTION TO FLUID PROCESS EQUIPMENT FOR MOYNO PUMP PARTS

The Department of Purchases & Supplies has solicited bids for Moyno pump repair parts as requested by Water Pollution Control Facilities; and

Fluid Process Equipment, 4797 Campus Dr., Kalamazoo, Michigan was the lowest responsive bidder from five solicitations for said requirements. Funding for said services will come from accounts 590-550.100-977.000 (\$7,825.54), 590-550.202-977.000 (\$10,000.06); and

IT IS RESOLVED, That the Department of Purchases & Supplies, upon the Emergency Manager's approval, is hereby authorized to issue a purchase order to Fluid Process Equipment for Moyno pump repair parts in an amount not to exceed \$17,825.60. (Sewer Fund)

Approved-Purchasing Department



Derrick F. Jones
Purchasing Department

Approved as to Funds



Jerry Ambrose
Director of Finance

Approved as to Form



Peter M. Bade
City Attorney

EM DISPOSITION:

ENACT ☒ FAIL ☐

DATED 4-3-12



Michael K. Brown, Emergency Manager

020812 – KRN

RESOLUTION STAFF REVIEW

January 25, 2012

Agenda Item Title: Moyno Repair Parts

Prepared By: Robert J. Case, WPC Supervisor

Background/Summary of Proposed Action:

The Moyno sludge cake pumps convey the dewatered sewage sludge from the conveyors into one of WPC's four (4) incinerators. Without replacement parts WPC will lose the ability to convey the sewage sludge to the incinerators and dispose of it.

Financial Implications:

Please issue a PO for the approved FY2012 budgeted amount of \$17,825.60. Use account number 590-550.300-977.000 (\$17,825.60) when issuing this PO.

Budgeted Expenditure? Yes ☒ No ☐ Please explain if no:


Account No.: 590-550.300-977.000

Pre-encumbered? Yes ☐ No ☒ Requisition: 1102125

Other Implications (i.e., collective bargaining): None.

Staff Recommendation: Recommend Approval

Staff Person:



(Dept Head)