

14-5197

(Bid No. 14000100)

EM SUBMISSION NO.: EME 312 2014

PRESENTED: 6-9-14

ADOPTED: 6-13-14

BY THE EMERGENCY MANAGER:

**RESOLUTION TO RS TECHNICAL SERVICES FOR CHLORINE EMERGENCY/SAFETY  
SHUT OFF VALVES**

BY THE EMERGENCY MANAGER

**RESOLUTION**


The Department of Purchases and Supplies has solicited a bid for chlorine emergency/safety shut off valves as requested by the Utilities Department/Water Plant Facility and Water Pollution Control Facility ; and

RS Technical Services, 695 Lincoln Lake Ave., Lowell, MI is the lowest responsive bidder from four solicitations for said requirements. The funding for this purchase will come from the following account numbers: 590-550.300-977.00 (\$44,886.50) 591-545.300-977.000 (\$29,176.00); and

IT IS RESOLVED, that the Department of Purchases and Supplies, upon the Emergency Manager's approval, is hereby authorized to issue purchase orders to RS Technical Services for chlorine emergency/safety shut off valves in an amount not to exceed \$74,062.50. (Sewer Fund, Water Fund)


APPROVED-PURCHASING DEPT:

APPROVED AS TO FINANCE:

  
Derrick Jones, Purchasing Manager

  
for Gerald Ambrose, Finance Director

APPROVED AS TO FORM:

  
Peter M. Bade, City Attorney

**EFM DISPOSITION:**

ENACT ✓ REFER TO COUNCIL \_\_\_\_\_ FAIL \_\_\_\_\_

  
Darnell Earley, Emergency Manager

DATED: 6-13-14

---

The shut off valves are designed to maintain the pressure in the line between 10 and 15 psi.

C:\Users\djones\Downloads\Chlorine SSOV resstaff.doc