

Section 00 9113 Addendum No. 02

WPC Sludge Dewatering Improvements Rehabilitation Project
Proposal No. 20000582
City of Flint, Michigan 48502

To all prospective bidders and others concerned, YOU ARE HEREBY ADVISED THAT the Contract Documents for the above referenced Project are revised in the following particulars:

<u>Section</u>	<u>Description of Change</u>
41 1213.60	Items C and D in Article 1.02 of Section 41 1213.60 shall be deleted in their entirety and subsequent items shall be renumbered accordingly.
41 1213.60	<p>The following sentence shall be deleted in its entirety from Article 2.01.A of Section 41 1213.60 (page 41 1213.60-3):</p> <p>“...Stators for sludge pumps shall have Buna elastomer. The sludge pump rotors shall be constructed of 316 SS. Additionally the sludge pump rotors...”</p>
41 1213.60	<p>The following sentence shall be deleted in its entirety from Article 2.01.C of Section 41 1213.60 (page 41 1213.60-3):</p> <p>“... The walls of the hopper shall be vertical to minimize bridging. Additionally, the auger speed shall be adjustable independent of the pump speed so that the sludge bridge can be eliminated per the actual process requirements.”</p>
41 1213.60	<p>Delete Article 2.01.H of Section 41 1213.60 in its entirety and replace with the following (page 41 1213.60-4):</p> <p>H. Run Dry Protection: The stator shall be fitted with a sensor sleeve and thermistor sensor. A controller shall also be provided and shall be included in the control panel. The controller shall monitor the stator temperature and activate a shutdown and alarm sequence if the stator temperature reaches the adjustable limit on the controller. The controller shall include a manual local and remote reset function. Input to the controller shall be 24V DC.</p>
46 3300	<p>Article 2.02.A.3.e of Section 46 3300 shall be revised to read as follows:</p> <p>e. Double walled polyethylene or fiberglass reinforced plastic tank with minimum secondary containment of volume of 115%.</p>

This Addendum is hereby incorporated into the original Contract Documents for the bidding referred to above and is considered as binding as though originally appearing therein. RECEIPT OF THIS ADDENDUM MUST BE NOTED in the place provided on the Proposal page 00 4243-1 and dated **June 24, 2020**.

