

CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT

SUPPLY NAME: CITY of FLINT WATER PLANT
WSSN: 2310

Michael Glasgow
 Operator-in-Charge

February 2015
 Month/Year

F-1R, F-2
 Certification of Operator-in-Charge

F-1
 Water Plant Classification


 Signature of Operator-in-Charge

Genesee
 County

Treatment Rate and Filter Data

Maximum Treatment Rate:	<u>25.3</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>86</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.4</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.3</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>2.4%</u>	Percent of Treated Water

Chemical Data

Chlorine on hand:	<u>8,000</u> lb.	Est. supply:	<u>8</u> days
Primary Coagulant (Ferric Chloride) on hand:	<u>125,000</u> lb.	Est. supply:	<u>3</u> days
Lime (CaO) on hand:	<u>397</u> tons	Est. supply:	<u>31</u> days
Fluoride on Hand:	<u>26,600</u> lb.	Est. supply:	<u>40</u> days
Cost of All Chemicals per Million Gallons:	<u>n/a</u> dollars		
Total Power Cost per Million Gallons:	<u>n/a</u> dollars		

Remarks

	Confluence Point # 1 (N)	Confluence Point # 2 (S)
Number of filter confluence samples > 0.3 NTU:	<u>1</u>	<u>0</u>
Number of filter confluence samples collected:	<u>218</u>	<u>218</u>
Percent of filter confluence samples > 0.3 NTU:	<u>0.5%</u>	<u>0.0%</u>
Number of filter confluence samples > 1 NTU	<u>0</u>	<u>0</u>

Did any individual filter exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart? If yes , attach specific filter(s) information and indicate required follow-up status.	<u>NO</u>
0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation? If yes , attach specific filter(s) information and indicate required follow-up status.	<u>NO</u>
1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months? If yes , attach specific filter(s) information and indicate required follow-up status.	<u>NO</u>
2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months? If yes , attach specific filter(s) information and indicate required follow-up status.	<u>NO</u>
Was continuous (every 15 minutes) filter monitoring equipment off-line during the month? If yes , indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.	<u>NO</u>
Did POE disinfectant residual fall below 0.2 ppm during the month? If yes , indicate date(s) and duration on a separate sheet.	<u>NO</u>
Was minimum C*T credit achieved for the entire month? If no , indicate on a separate sheet the date(s) not achieved.	<u>YES</u>
Was continuous POE chlorine residual monitoring equipment off-line during the month? If yes , indicate date(s) and duration on a separate sheet.	<u>NO</u>

WSSN: 2310

Date	Turbidity, Units												Point of Entry Plant Tap NTU
	Confluence Point. No.1 (N) North						Confluence Point. No.2 (S) South						
	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	
1	8	0.07	0.09	6	0	0	8	0.06	0.09	6	0	0	0.07
2	7	0.06	0.10	6	0	0	7	0.06	0.07	6	0	0	0.07
3	8	0.07	0.15	6	0	0	8	0.06	0.07	6	0	0	0.08
4	8	0.05	0.08	6	0	0	8	0.05	0.07	6	0	0	0.07
5	8	0.07	0.10	6	0	0	8	0.06	0.07	6	0	0	0.07
6	7	0.06	0.08	6	0	0	7	0.06	0.08	6	0	0	0.07
7	8	0.06	0.07	6	0	0	8	0.06	0.06	6	0	0	0.07
8	8	0.06	0.07	6	0	0	8	0.06	0.07	6	0	0	0.06
9	8	0.07	0.09	6	0	0	8	0.05	0.06	6	0	0	0.09
10	7	0.06	0.07	6	0	0	7	0.05	0.06	6	0	0	0.08
11	8	0.06	0.07	6	0	0	8	0.05	0.07	6	0	0	0.07
12	8	0.06	0.08	6	0	0	8	0.06	0.08	6	0	0	0.06
13	8	0.06	0.09	6	0	0	8	0.09	0.18	6	0	0	0.08
14	8	0.06	0.09	6	0	0	8	0.06	0.10	6	0	0	0.05
15	8	0.06	0.08	6	0	0	8	0.07	0.09	6	0	0	0.07
16	8	0.06	0.08	6	0	0	8	0.05	0.07	6	0	0	0.06
17	8	0.06	0.08	6	0	0	8	0.07	0.09	6	0	0	0.07
18	8	0.07	0.09	6	0	0	8	0.07	0.09	6	0	0	0.07
19	8	0.07	0.09	6	0	0	8	0.06	0.08	6	0	0	0.07
20	8	0.07	0.08	6	0	0	8	0.07	0.10	6	0	0	0.07
21	8	0.08	0.14	6	0	0	8	0.08	0.10	6	0	0	0.08
22	8	0.09	0.12	6	0	0	8	0.10	0.13	6	0	0	0.08
23	8	0.13	0.16	6	0	0	8	0.07	0.10	6	0	0	0.10
24	7	0.19	0.36	6	1	1	7	0.14	0.18	6	0	0	0.17
25	8	0.08	0.10	6	0	0	8	0.10	0.12	6	0	0	0.11
26	8	0.13	0.17	6	0	0	8	0.13	0.18	6	0	0	0.14
27	8	0.19	0.29	6	0	0	8	0.15	0.18	6	0	0	0.15
28	8	0.20	0.27	6	0	0	8	0.13	0.18	6	0	0	0.15
Avg.	8	0.08	0.12	6	0	0	8	0.07	0.10	6	0	0	
Max.	8	0.20	0.36	6	1	1	8	0.15	0.18	6	0	0	0.17
Min.	7	0.05	0.07	6	0	0	7	0.05	0.06	6	0	0	

Date	Fluoride Applied as F- mg/L	Fluoride Analysis (mg/L)			Chlorine Application (mg/L)			Chlorine Residual (mg/L)					
					Intermediate Chlorine	Post Chlorine	Total Chlorine	Filtered		3 MG Well		Tap	
		Raw	Tap	Dist.				Free	Total	Free	Total	Free	Total
1	0.3	0.23	0.53		1.6	3.1	4.7	0.3	0.6	2.6	3.0	2.5	2.9
2	0.3	0.22	0.48		1.8	2.9	4.7	0.3	0.5	2.4	2.7	2.2	2.5
3	0.3	0.23	0.51	0.52	1.9	3.0	4.9	0.8	1.2	2.6	2.9	2.4	2.7
4	0.4	0.22	0.53		1.9	3.0	4.9	0.6	0.8	2.8	3.0	2.7	3.0
5	0.3	0.22	0.53		1.9	2.9	4.8	0.5	0.7	2.6	3.0	2.2	2.5
6	0.4	0.22	0.57		2.0	3.0	5.0	0.8	1.0	2.7	3.0	2.3	2.8
7	0.3	0.22	0.58		2.1	2.7	4.8	0.3	0.6	2.6	2.9	2.1	2.4
8	0.4	0.23	0.56		2.1	2.7	4.8	0.6	0.8	2.7	3.0	2.2	2.5
9	0.4	0.22	0.64		1.9	2.8	4.7	0.4	0.6	2.7	3.0	2.3	2.6
10	0.4	0.24	0.63	0.56	2.2	2.9	5.1	0.5	0.7	2.8	3.1	2.1	2.4
11	0.4	0.21	0.55		2.2	2.8	5.0	0.7	0.9	2.6	2.8	1.9	2.4
12	0.4	0.21	0.58		2.2	2.7	4.9	0.6	0.8	2.5	2.8	2.1	2.5
13	0.4	0.23	0.59		2.2	2.4	4.6	0.4	0.6	2.0	2.5	1.7	2.2
14	0.4	0.22	0.55		2.2	2.2	4.4	0.6	0.8	2.3	2.6	1.5	2.1
15	0.4	0.21	0.60		2.1	2.2	4.3	0.4	0.6	2.0	2.4	1.9	2.2
16	0.4	0.23	0.59		2.1	2.2	4.3	0.4	0.6	2.1	2.4	1.8	2.1
17	0.4	0.21	0.61	0.54	2.1	2.3	4.4	0.8	1.0	2.0	2.4	1.3	1.7
18	0.3	0.23	0.58		2.0	2.2	4.2	0.3	0.6	1.9	2.4	1.5	2.0
19	0.3	0.24	0.64		2.2	2.1	4.3	0.6	0.8	2.0	2.4	1.7	2.2
20	0.4	0.23	0.56		2.2	2.1	4.3	0.7	1.0	2.0	2.5	1.5	1.9
21	0.4	0.24	0.61		2.2	2.1	4.3	0.5	0.7	1.7	2.2	1.5	2.0
22	0.4	0.23	0.55		2.2	2.1	4.3	0.4	0.6	2.0	2.3	1.7	1.9
23	0.3	0.24	0.64		2.2	2.2	4.4	0.5	0.6	2.0	2.1	1.5	1.6
24	0.3	0.24	0.56	0.54	2.3	2.6	4.9	0.4	0.6	2.5	3.3	2.1	2.5
25	0.3	0.23	0.62		2.3	2.6	4.9	0.5	0.7	2.5	2.9	2.4	2.7
26	0.3	0.23	0.54		2.3	2.7	5.0	0.5	0.7	2.7	3.1	2.5	3.0
27	0.3	0.24	0.56		2.3	2.5	4.8	0.6	0.8	2.3	2.9	2.1	2.5
28	0.3	0.24	0.56		2.3	2.5	4.8	0.6	0.8	2.3	2.8	1.9	2.5

Avg.	0.35	0.23	0.57	0.54	2.1	2.6	4.7	0.5	0.7	2.4	2.7	2.0	2.4
Max.	0.40	0.24	0.64	0.56	2.3	3.1	5.1	0.8	1.2	2.8	3.3	2.7	3.0
Min.	0.30	0.21	0.48	0.52	1.6	2.1	4.2	0.3	0.5	1.7	2.1	1.3	1.6

WSSN: 2310

Date	pH (S.U.)		Total Hardness as CaCO ₃ (mg/L)		Total Alkalinity as CaCO ₃ (mg/L)		Non-Carbonate Hardness as CaCO ₃ (mg/L)		Calcium as Ca ²⁺ (mg/L)		Magnesium as Mg ²⁺ (mg/L)		Chloride as Cl ⁻ (mg/L)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
1	7.78	7.91	339	198	273	60	66	138	109.0	56.9	17.5	14.1	51	98
2	7.92	7.64	343	203	274	77	69	126	110.6	60.1	15.6	12.6	52	91
3	7.75	8.69	344	176	276	62	68	114	113.8	54.5	13.6	10.2	57	90
4	8.04	7.88	346	176	277	62	69	114	114.6	54.5	14.6	10.2	49	88
5	7.77	7.56	349	183	284	63	65	120	118.6	60.9	12.6	7.3	55	89
6	7.92	7.63	350	180	276	52	74	128	117.8	52.9	13.6	11.7	54	95
7	8.07	7.76	348	185	282	68	66	117	113.8	54.5	15.6	11.7	52	92
8	8.05	7.57	347	181	278	50	69	131	111.4	51.3	16.5	12.6	51	91
9	8.11	7.66	349	183	280	62	69	121	112.2	52.9	16.5	12.2	53	94
10	7.95	7.65	350	168	284	47	66	121	113.0	57.7	16.5	6.8	56	95
11	7.97	7.76	345	173	274	54	71	119	109.0	49.7	17.9	12.6	51	92
12	7.85	7.66	342	169	274	51	68	118	117.8	59.3	12.2	5.3	55	92
13	7.77	7.70	345	170	267	53	78	117	121.0	57.7	11.2	4.9	54	90
14	7.86	7.54	344	173	269	52	75	121	125.0	63.3	7.3	3.9	56	93
15	8.00	7.73	349	176	280	53	69	123	113.0	50.5	16.0	12.2	50	94
16	7.89	7.68	353	169	285	47	68	122	123.4	53.7	10.7	8.7	55	95
17	8.05	7.92	360	172	281	49	79	123	118.6	48.9	15.6	11.7	53	92
18	7.96	7.97	352	218	282	102	70	116	125.9	78.6	8.7	5.3	54	91
19	8.11	7.82	358	208	291	91	67	117	120.2	59.3	14.6	13.1	53	92
20	7.93	7.90	362	207	286	94	76	113	133.1	76.2	7.3	4.4	55	87
21	8.00	8.06	362	214	284	98	78	116	133.9	76.2	6.8	4.4	54	86
22	7.98	8.03	366	227	294	113	72	114	116.2	67.3	18.5	14.1	52	88
23	8.07	8.31	361	225	293	112	68	113	121.8	68.9	14.1	12.6	52	86
24	7.95	7.85	361	227	289	101	72	126	133.9	78.6	5.8	6.8	54	88
25	8.03	8.14	365	244	295	127	70	117	118.6	77.8	16.5	11.7	55	89
26	7.91	7.88	365	235	288	108	77	127	132.3	86.6	8.3	4.9	55	89
27	7.96	7.85	354	241	291	117	63	124	131.5	91.4	6.3	2.9	57	89
28	7.90	7.72	358	228	228	115	130	113	127.5	84.2	9.7	3.9	54	87
Avg.	7.95	7.84	352	197	280	76	73	120	119.9	63.7	12.9	9.0	54	91
Max.	8.11	8.69	366	244	295	127	130	138	133.9	91.4	18.5	14.1	57	98
Min.	7.75	7.54	339	168	228	47	63	113	109.0	48.9	5.8	2.9	49	86

Date	Total Coliform						Standard Plate Count (Simplate MPN)		Conductivity (mS)	Temp. C	Color		Odor	
	Raw (Coliart MPN)		Filter Confluence (N&S)		Plant Tap		Raw	Tap			Raw	Tap	Raw	Tap
	# Samples	Count	# Samples	# pos	# Samples	# pos			Raw	Tap				
1	1	41	12	0	1	0	150	< 2	0.53	4.0				
2	1	117	12	0	1	0	132	< 2	0.55	4.2				
3	1	96	12	0	1	0	146	< 2	0.49	4.3				
4	1	86	12	0	1	0	90	< 2	0.51	4.1				
5	1	105	12	0	1	0	183	< 2	0.51	3.5				
6	1	276	12	0	1	0	128	< 2	0.50	2.4				
7	1	124	12	0	1	0	97	< 2	0.50	3.8				
8	1	120	12	0	1	0	80	< 2	0.48	3.8				
9	1	104	12	0	1	0	90	< 2	0.51	4.2				
10	1	93	12	0	1	0	132	< 2	0.50	4.0				
11	1	115	12	0	1	0	83	< 2	0.47	4.3				
12	1	115	12	0	1	0	93	< 2	0.46	3.8				
13	1	153	12	0	1	0	80	< 2	0.50	4.5				
14	1	154	12	0	1	0	93	< 2	0.48	3.6				
15	1	138	12	0	1	0	83	< 2	0.52	0.5				
16	1	179	12	0	1	0	137	< 2	0.50	0.7				
17	1	365	12	0	1	0	166	< 2	0.50	1.2				
18	1	219	12	0	1	0	177	< 2	0.51	1.7				
19	1	153	12	0	1	0	112	< 2	0.45	2.2				
20	1	192	12	0	1	0	62	< 2	0.56	1.9				
21	1	142	12	0	1	0	116	< 2	0.51	4.1				
22	1	160	12	0	1	0	146	< 2	0.55	2.1				
23	1	129	12	0	1	0	112	< 2	0.58	1.0				
24	1	135	12	0	1	0	100	< 2	0.61	3.4				
25	1	145	12	0	1	0	156	< 2	0.61	2.0				
26	1	115	12	0	1	0	108	< 2	0.61	1.2				
27	1	86	12	0	1	0	74	< 2	0.61	3.3				
28	1	84	12	0	1	0	65	< 2	0.56	3.3				
Avg.									0.52	3.0				
Max.		365					183	0	0.61	4.5				
Min.									0.45	0.5				

Date	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WS	Number of Samples
1											0
2											0
3	0.7	1.5	1.5	1.5	1.5	0.2	1.7	1.7	1.3	2.0	10
4											0
5	1.0	1.7	1.7	1.7	1.1	0.2	1.8	2.0	0.7	1.4	10
6											0
7											0
8											0
9											0
10	1.0	1.2	1.5	1.3	1.0	0.2	2.0	1.9	0.7	1.0	10
11	1.0	1.3	1.7	1.7	0.9	0.3	1.7	2.3	0.5	0.9	10
12	0.4	1.4	2.3	1.8	0.7	0.2	1.9	2.2	0.5	1.2	10
13											0
14											0
15											0
16											0
17	1.1	0.7	1.2	1.5	0.7	0.2	1.1	1.3		1.5	9
18	1.2	0.8	1.6	1.2	0.8	0.2	1.8	1.7		1.4	9
19	0.9	0.7	1.3	1.0	0.7	0.2	0.8	1.3		1.0	9
20											0
21											0
22											0
23	1.3	0.8	1.3	1.1	0.6	0.2	0.6	1.5		0.8	9
24	1.5	1.1	1.7	1.2	1.0	0.2	2.5	2.2		2.3	9
25											0
26	1.7	1.4	2.0	1.5	1.1	0.3	1.8	1.8		2.1	9
27											0
28											0

Distribution Sample Summary	
Total # of routine distribution samples analyzed	104
Total # of routine distribution samples required	100

Distribution Bacteriological Summary	
Total # of positive routine distribution samples	0
Percent of routine distribution samples positive	0%

See page 9 for positive sample information.

Distribution Disinfectant Total Residual Summary	
Percentage of samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	1.22

Date	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										Number of Samples
	1	2	3	4	5	6	7	8	CS	WS	
1											0
2											0
3	1.0	1.8	1.8	1.9	1.8	0.3	2.0	1.9	1.7	2.4	10
4											0
5	1.3	2.1	2.0	2.0	1.3	0.4	2.1	2.3	1.0	1.6	10
6											0
7											0
8											0
9											0
10	1.3	1.5	1.9	1.6	1.3	0.4	2.4	2.2	1.0	1.3	10
11	1.2	1.5	1.8	1.9	1.1	0.4	1.9	2.6	0.7	1.2	10
12	0.5	1.6	2.4	2.0	0.9	0.4	2.1	2.4	0.6	1.4	10
13											0
14											0
15											0
16											0
17	1.3	1.0	1.4	1.8	0.9	0.3	1.5	1.8		1.7	9
18	1.5	1.0	1.9	1.5	1.0	0.3	2.1	2.0		1.7	9
19	1.3	1.1	1.6	1.5	1.0	0.3	1.0	1.7		1.3	9
20											0
21											0
22											0
23	1.5	1.0	1.6	1.3	0.8	0.3	0.8	1.8		1.2	9
24	1.7	1.3	1.9	1.4	1.2	0.4	2.8	2.4		2.5	9
25											0
26	1.9	1.6	2.4	1.7	1.4	0.5	2.1	2.0		2.5	9
27											0
28											0

Distribution Disinfectant Total Residual Summary	
Percent samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	1.5

