

## **Section 00 9113 Addendum No. 03**

WPC Sludge Dewatering Improvements Rehabilitation Project  
Proposal No. 20000582  
City of Flint, Michigan 48502

To all prospective bidders and others concerned, YOU ARE HEREBY ADVISED THAT the Contract Documents for the above referenced Project are revised in the following particulars:

<u><b>Section</b></u>	<u><b>Description of Change</b></u>
46 3300	<p>Article 2.03.A.3.e of Section 46 3300 shall be revised to read as follows:</p> <ul style="list-style-type: none"><li>a. Dilution water flow rate shall be measured utilizing a variable area flow meter capable of accurately measuring flow throughout the range specified above. <del>Flow sensor mounting shall be via insertion to permit easy removal for periodic cleaning.</del></li><li>c. Unit shall have a variable rate control valve to manually proportion water flow to polymer flow for polymer / water ratio control. Valves that diminish mixing energy in the non-mechanical stage shall not be used.</li></ul>

This Addendum is hereby incorporated into the original Contract Documents for the bidding referred to above and is considered as binding as though originally appearing therein. RECEIPT OF THIS ADDENDUM MUST BE NOTED in the place provided on the Proposal page 00 4243-1 and dated **June 25, 2020**.