



# City of Flint

## Department of Purchases & Supplies

---

February 18, 2020

TO: All Proposers

FROM: Joyce A. McClane, CPPB  
Purchasing Manager

SUBJECT: Addendum #1 – **Proposal #20000561 – Dort Reservoir Rehabilitation**

### Notice to All Bidders:

This Addendum is issued to modify, change, delete from, add to, explain or correct the original Request for Proposal and is hereby made a part of it. In case of conflict between the Request for Proposal and this Addendum, this Addendum shall govern. Prime bidders will need to pass the addendum information on to any subcontractors they may be using for this project.

Below please find our answers to the questions from vendors and attached copies of installation guides. The answers are in **RED**.

- The table of contents in the contract book references several specifications section that do appear to be part of the current document. Can you please release these missing sections?
- What is the interior height of the reservoir? **Approximately 20'**
- Will the reservoir be completely dewatered and cleaned prior to contractor mobilization? **Has been dewatered – cleaning would be done by the contractor in areas where necessary.**
- Will any interior reservoir cleaning be required in addition to removal of construction debris? **Contractor is to include a final cleaning of the entire reservoir after the repair work is completed.**
- What is the total repair height of the column encasement shown on Detail 6/S1.4? **Assume average height of 16 feet.**
- What is the assumed concrete repair depth for bidding purposes in regards to detail 1/S1.1? **Assume average depth of 2 ½ inches.**
- Does the quantity on the bid form for interior wall expansion joint include Detail 5/S1.3 (listed as 70 LF) and note 7 on sheet S1.0 (listed as 660 LF)? **Item #5 is to include both interior concrete and CMU joint repair per LF of wall with one LF**



# City of Flint

## Department of Purchases & Supplies

---

All other bidding terms, requirements, and conditions continue as indicated in the remaining original bid documents.

The Purchasing Manager, Joyce McClane, is an officer for the City of Flint with respect to this RFP. All questions and/or comments should be directed to her at this email address: [jmcclane@cityofflint.com](mailto:jmcclane@cityofflint.com).

In the submission of their proposal, Proposer must acknowledge receipt of this addendum. Proposer shall acknowledge this addendum by signing and returning one copy of this notice with their submission.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City / State / Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_