



City of Flint

Department of Purchases & Supplies

Sheldon A. Neeley

TO: All Proposers
FROM: Lauren Rowley
Purchasing Manager
DATE: **November 5, 2021**
SUBJECT: **Addendum #03** – Proposal #22000508 –2MG ELEVATED WATER TOWER
REHABILITATION PROGRAM (4) YEARS

This addendum has been issued because of the following:

Q1: Can an alternative tank mixer be proposed for this project?

A1: A different brand or style of mixers can be installed as long as there is a proposed mixing system. The system can communicate with either our current SCADA system or a small control panel in the tank house to notify us when they are/are not running.

All other bidding terms, requirements, and conditions continue as indicated in the remaining original bid documents.

The Purchasing Manager, Lauren Rowley, is an officer for the City of Flint with respect to this RFP.

In the submission of their proposal, Proposer must acknowledge receipt of this addendum. Proposer shall acknowledge this addendum by signing and returning one copy of this notice with their submission.

Company Name: _____

Address: _____

City / State / Zip: _____

Telephone: _____ Fax: _____ Email: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

Thank you,

Lauren Rowley
Purchasing Manager