

**FINANCE DEPARTMENT  
DIVISION OF PURCHASES & SUPPLIES**



Sheldon A. Neeley, Mayor

**PROPOSAL NO. 21000604**

**LIFT STATION PUMPS**

**Date Posted: 02/23/21**

# CITY OF FLINT PROPOSAL NO. 21000604

## LIFT STATION PUMPS

Based on the COVID-19 public health threat, it is recommended that people not gather in groups larger than 10 people in order to "flatten" the curve and slow the spread of the virus. If dropping off a bid, please wear a mask.

Thank you.

**CITY OF FLINT**  
**FINANCE DEPARTMENT**  
**DIVISION OF PURCHASES AND SUPPLIES**  
City Hall, 1101 S. Saginaw Street, Room #203 – Flint, Michigan 48502  
(810) 766-7340      www.cityofflint.com



Sheldon Neeley  
Mayor

**REQUEST FOR PROPOSALS**

**OWNER/RETURN TO:**

THE CITY OF FLINT  
FINANCE DEPARTMENT – DIVISION OF PURCHASES AND SUPPLIES  
1101 S. SAGINAW ST., ROOM 203, 2nd FLOOR  
FLINT, MI 48502

**PROPOSAL NO: 21000604**

**SCOPE OF WORK:**

The City of Flint, Finance Department of Purchases & Supplies, is soliciting sealed bids for providing:

**LIFT STATION PUMPS**

Per the attached additional requirements.

If your firm is interested in providing the requested services, please submit one (1) Original Hard Copy Unbound with original signatures and one (1) Electronic copy of your bid.

Proposal submittal information **MUST** be received by the following dates and times:

1. The mail in **HARD COPY** with the original signature (signed documents) must be received by **Tuesday, March 9, 2021 by 3:00 PM (EST), City of Flint, Finance Department - Division of Purchases and Supplies, 1101 S. Saginaw St., Room 203, Flint, MI, 48502.** Bids must be in a sealed envelope clearly identifying the proposal name and proposal number.
2. **Electronic Copy**, please email to **PurchasingBids@cityofflint.com** by **Tuesday, March 9, 2021 by 1:00 PM.** Please note that in the subject line of the email, type in the proposal name and number.
3. Faxed bids are not accepted.
4. Both mail in proposal and electronic submittal must be received by due date and time.

All additional proposal documents, requirements, addendums, specifications, and plans/drawings (if utilized) are available on the Purchasing page of the City of Flint's web site at <https://www.cityofflint.com/finance/purchasing/bids-2/> under "open bids" and the specific bid or proposal number assigned to this notice.

Effective immediately upon release of these Bidding Documents, and until notice of contract award, all official communications from proposers regarding the requirements of this Bid shall be directed to:

Joyce A. McClane  
810-766-7340  
[jmcclane@cityofflint.com](mailto:jmcclane@cityofflint.com)

The City, or designee, shall distribute all official changes, modifications, responses to questions or notices relating to the requirements of this Bid. Addendum to this Bid may be developed and shared with all Vendors. Any other information of any kind from any other source shall not be considered official, and proposers relying on other information do so at their own risk.

**NOTICE TO VENDOR** Offers, subject to the conditions made a part hereof, will be received at this office, **1101 S. Saginaw St., Flint, MI 48502 for the following:**

All additional proposal documents, requirements, addendums, specifications, and plans/drawings (if utilized) are available on the Purchasing page of the City of Flint's web site at <https://www.cityofflint.com/finance/purchasing/bids-2/> under "open bids" and the specific bid or proposal number assigned to this notice.

New vendors should complete and submit a vendor application, IRS W-9 Form, and Vendor ACH Payment Authorization Form with the City of Flint. Links to these forms are available at <https://www.cityofflint.com/finance/accounts-payable-department/>.

Results may be viewed next business day online EXCEPT when a bid is under review. The bidders/public will only see the names of the bidders that submitted a bid, not their cost. This will protect the bidders cost in case there is a re-bid.

<https://www.cityofflint.com/finance/purchasing/results/> under "bid results".

---

City of Flint has partnered with BidNet as part of the [MITN Purchasing Group](#) (branded page link) to post bid opportunities to this site. As a vendor, you can register with the [MITN Purchasing Group](#) and be sure that you see all available bids and opportunities. By selecting automatic bid notification, your company will receive emails once the City of Flint has a bid opportunity that matches your company's business. In addition, the site handles bid opportunities, RFPs, and RFQs for other member governmental agencies throughout Michigan. City of Flint looks forward to providing you with more bid information and simplifying the entire bid, proposal, and quote processes for everyone involved. We appreciate your cooperation and welcome your participation. If you need help registering, please call the MITN Purchasing Group support department toll free 1-800-835-4603 option #2.

Link to City of Flint open solicitations:

[MITN Purchasing Group](#) (branded page link)

---

Any questions regarding the proposal process may be directed to Purchasing in writing by no later than 03/01/21 by 1:00 PM to email address: [jmcclane@cityofflint.com](mailto:jmcclane@cityofflint.com).

Sincerely,



Handwritten signature of Joyce A. McClane in blue ink.

Joyce A. McClane, CPPB Purchasing Manager

**THIS PAGE INTENTIONALLY LEFT BLANK**

## INSTRUCTIONS TO VENDORS

- 1) **PRE-BID INFORMATION AND QUESTIONS:** Each bid that is timely received will be evaluated on its merit and completeness of all requested information. In preparing bids, Bidders are advised to rely only upon the contents of this Request for Proposals (RFP) and accompanying documents and any written clarifications or addenda issued by the City of Flint. If a Bidder finds a discrepancy, error or omission in the RFP package, or requires any written addendum thereto, the Bidder is requested to notify the Purchasing contact noted on the cover of this RFP, so that written clarification may be sent to all prospective Bidders. **THE CITY OF FLINT IS NOT RESPONSIBLE FOR ANY ORAL INSTRUCTIONS.** All questions must be submitted in writing to the Finance Department of Purchases and Supplies before any pre-bid deadline (if specified) or at least one (1) week prior to the proposal opening date indicated on the front of this document.
  
- 2) **RFP MODIFICATIONS:** The City of Flint has the right to correct, modify or cancel the RFP, in whole or in part, or to reject any Bid, in whole or in part, within the discretion of the City of Flint, or their designee. If any such changes are made, all known recipients of the RFP will be sent a copy of such changes. If any changes are made to this RFP document by any party other than the City of Flint, the original document in the City of Flint's files takes precedence.
  
- 3) **PROPOSAL SUBMISSION:**
  - a) The Bidder must include the following items, or the proposal may be deemed non-responsive:
    - i) All forms contained in this RFP, fully completed.
  
  - b) Bids must be submitted to the Finance Department of Purchases and Supplies, City of Flint, 1101 S. Saginaw Street, Room 203, Flint, Michigan 48502 by the date and time indicated as the deadline. The Purchasing Department time stamp will determine the official receipt time. It is each Bidder's responsibility to insure that their proposal is time stamped by the Purchasing Department by the deadline. This responsibility rests entirely with the Bidder, regardless of delays resulting from postal handling or for any other reasons. Proposals will be accepted at any time during the normal course of business only, said hours being 8:00 a.m. to 5:00 p.m. local time, Monday through Friday, legal holidays as exception.
  
  - c) Bids must be enclosed in a sealed, non-transparent envelope, box or package, and clearly marked on the outside with the following: RFP Title, RFP Number, Deadline and Bidder's name.
  
  - d) Submission of a bid establishes a conclusive presumption that the Bidder is thoroughly familiar with the Request for Proposals (RFP), and that the Contractor understands and agrees to abide by each and all of the stipulations and requirements contained therein.
  
  - e) All prices and notations must be typed or printed in ink. No erasures are permitted. Mistakes may be crossed out and corrections must be initialed in ink by the person(s) signing the bid.
  
  - f) Proposals sent by email, facsimile, or other electronic means will not be considered unless specifically authorized in this RFP.
  
  - g) All costs incurred in the preparation and presentation of the bid are the Bidder's sole responsibility; no pre-bid costs will be reimbursed to any Bidder. All documentation submitted with the proposal will become the property of the City of Flint.
  
  - h) Proposals must be held firm for a minimum of 120 days.

- 4) **EXCEPTIONS:** Bidder shall clearly identify any proposed deviations from the Terms or Scope in the Request for Proposals. Each exception must be clearly defined and referenced to the proper paragraph in this RFP. The exception shall include, at a minimum, the proposed substitute language and opinion as to why the suggested substitution will provide equivalent or better service and performance. If no exceptions are noted in the bid, the City of Flint will assume complete conformance with this specification and the successful Bidder will be required to perform accordingly. Bids not meeting all requirements may be rejected.
- 5) **DUPLICATE BIDS:** No more than one (1) bid from any Bidder including its subsidiaries, affiliated companies and franchises will be considered by the City of Flint. In the event multiple proposals are submitted in violation of this provision, the City will have the right to determine which bid will be considered or, at its sole option, reject all such multiple proposals.
- 6) **WITHDRAWAL:** Bids may only be withdrawn by written notice prior to the date and time set for the opening of bids. No bid may be withdrawn after the deadline for submission.
- 7) **REJECTION/GOOD STANDING:** The City of Flint reserves the right to reject any or all bids, or to accept or reject any bid in part, and to waive any minor informality or irregularity in bids received if it is determined by the City of Flint, or their designee, that the best interest of the City will be served by doing so. No bid will be considered from any person, firm or corporation in arrears or in default to the City on any contract, debt, taxes or other obligation, or if the Bidder is debarred by the City of Flint from consideration for a contract award pursuant to Section 18-21.5 (d) of Article IV of the "Purchasing Ordinance of the City of Flint".
- 8) **PROCUREMENT POLICY:** Procurement for the City of Flint will be handled in a manner providing fair opportunity to all businesses. This will be accomplished without abrogation or sacrifice of quality and as determined to be in the best interest of the City. The City of Flint and their officials have the vested authority to execute a contract, subject to City Council and Mayoral approval where required.
- 9) **BID SIGNATURES:** Bids must be signed by an authorized official of the Bidder. Each signature represents binding commitment upon the Bidder to provide the goods and/or services offered to the City of Flint if the Bidder is determined to be the lowest Responsive and Responsible Bidder.
- 10) **CONTRACT AWARD/SPLIT AWARDS:** The City of Flint reserves the right to award by item and/or group of items. The Bidder to whom the award is made will be notified at the earliest possible date. Tentative acceptance of the bid, intent to recommend award of a contract and actual award of the contract will be provided by written notice sent to the Bidder at the address designated in the bid if a separate Agreement is required to be executed. After a final award of the Agreement by the City of Flint, the Contractor/Vendor must execute and perform said Agreement. All proposals must be firm for at least 120 days from the due date of the proposal. If, for any reason, a contract is not executed with the selected Bidder within 14 days after notice of recommendation for award, then the City may recommend the next lowest responsive and responsible Bidder.

- 11) **NO RFP RESPONSE:** Bidders who receive this RFP but who do not submit a bid should return this RFP package stating "No Bid" and are encouraged to list the reason(s) for not responding. Failure to return this form may result in removal of the Bidder's name from all future lists.
- 12) **FREEDOM OF INFORMATION ACT (FOIA) REQUIREMENTS:** Bids are subject to public disclosure after the deadline for submission in accordance with state law.
- 13) **ARBITRATION:** Contractor/Vendor agrees to submit to arbitration all claims, counterclaims, disputes and other matters in question arising out of or relating to this agreement or the breach thereof. The Contractor's/Vendor's agreement to arbitrate shall be specifically enforceable under the prevailing law of any court having jurisdiction to hear such matters. Contractor's/Vendor's obligation to submit to arbitration shall be subject to the following provisions:
- a) Notice of demand for arbitration must be submitted to the City in writing within a reasonable time after the claim, dispute or other matter in question has arisen. A reasonable time is hereby determined to be fourteen (14) days from the date the party demanding the arbitration knows or should have known the facts giving rise to their claim, dispute or question. In no event may the demand for arbitration be made after the time when institution of legal or equitable proceedings based on such claim dispute or other matters in question would be barred by the applicable statute of limitation.
  - b) Within fourteen (14) days from the date that demand for arbitration is received by the City, each party shall submit to the other the name of one person to serve as an arbitrator. The two arbitrators together shall then select a third person, the three together shall then serve as a panel in all proceedings. Any decision concurred in by a majority of the three shall be a final binding decision.
  - c) The final decision rendered by said arbitrators shall be binding and conclusive and shall be subject to specific enforcement by a court of competent jurisdiction.
  - d) The costs of the arbitration shall be split and borne equally between the parties and such costs are not subject to shifting by the arbitrator.
  - e) This provision shall survive the expiration or termination of this Agreement in perpetuity.
- 14) **BID HOLD:** The City of Flint may hold bids for a period of one hundred twenty (120) days from opening, for the purpose of reviewing the results and investigating the qualifications of bidders prior to making an award.
- 15) **NONCOMPLIANCE:** Failure to deliver in accordance with specifications will be cause for the City of Flint and they may cancel the contract or any part thereof and purchase on the open market, charging any additional cost to the Contractor/Vendor.
- 16) **DISCLAIMER OF CONTRACTUAL RELATIONSHIP:** Nothing contained in these documents shall create any contractual relationship between the City and any Subcontractor or Sub-subcontractor.

- 17) **ERRORS AND OMISSIONS:** Bidder is not permitted to take advantage of any obvious errors or omissions in specifications.
- 18) **INTERPRETATION:** In the event that any provision contained herein shall be determined by a court of competent jurisdiction or an appropriate administrative tribunal to be contrary to the provision of law or to be unenforceable for any reason, then, to the extent necessary and possible to render the remainder of this Agreement enforceable, such provision may be modified or severed by such court or administrative tribunal having jurisdiction over this Agreement and the interpretation thereof, or the parties hereto, so as to, as nearly as possible, carry out the intention of the parties hereto, considering the purpose of the entire Agreement in relation to such provision.
- 19) **LAWS AND ORDINANCES:** The Bidder shall obey and abide by all of the laws, rules and regulations of the Federal Government, State of Michigan, Genesee County and the City of Flint, applicable to the performance of this Agreement, including, but not limited to, labor laws, and laws regulating or applying to public improvement, local government, and its operational requirements.
- 20) **LOCAL PREFERENCE:** Contractors/bidders located within the corporate city limits of Flint, Michigan may be given a seven percent (7%) competitive price advantage. Additionally, if the lowest responsible bidder is not located within the limits of the City of Flint, but is located within the County of Genesee, and said bidder does not exceed the bid of the lowest non-local bidder by more than three and one-half percent (3-1/2%), then said lowest Genesee County bidder may be determined to be the lowest responsible bidder, and make the award to such Genesee County bidder accordingly, subject to the approval of the City Council. If the lowest non-local bidder does not exceed that of any Proposers/bidders by (7%) inside the City of Flint or (3-1/2%) inside the County of Genesee, then the Purchasing Director shall be allowed to request that the lowest local vendor match the price offered by the lowest non-local vendor.
- 21) **MATERIAL WORKMANSHIP AND STANDARDS OF PERFORMANCE:** The Bidder agrees to exercise independent judgment and to complete performance under this Agreement in accordance with sound professional practices. In entering into this Agreement, the City is relying upon the professional reputation, experience, certification and ability of the Bidder by her/him/themselves or by others employed by her/him/them and working under their direction and control. The continued effectiveness of this Agreement during its term or any renewal term shall be contingent, in part, upon the Bidder maintaining her/his/their operating qualifications in accordance with the requirements of federal, state and local laws. All materials furnished must be new, of latest model and standard first grade quality, or best workmanship and design, unless otherwise expressly specified. Bidder, if required, must furnish satisfactory evidence of quality materials; offers of experimental or unproven equipment may be disregarded.
- 22) **MODIFICATIONS/CHANGES:** Any modification to this agreement must be in writing and signed by the authorized employee, officer, board or council representative authorized to make such modifications pursuant to the State law and local ordinances.
- 23) **NON-COLLUSION:** The Bidder acknowledges that by signing this document that she/he/they is/are duly authorized to make said offer on behalf of the company she/he/they represent(s) and that said bid is genuine and not sham or collusive and not made in the interests or on behalf of any person not therein named, and that she/he/they and said bidder have not directly induced or solicited any other

person(s) or corporation to refrain from responding to this solicitation and that she/he/they and said bidder have not in any manner sought by collusion to secure to themselves and said bidder any advantage over any other bidder.

24) **NON-DISCRIMINATION:** Pursuant to the requirements of 1976 P.A. 453 (Michigan Civil Rights Act) and 1976 P.A. 220 (Michigan Handicapped Rights Act), the local unit and its agent agree not to discriminate against any employee or applicant for employment with respect to hire, tenure, terms, conditions, or privileges of employment or a matter directly or indirectly related to employment because of race, color, religion, national origin, age, sex, height, weight, marital status or because of a handicap that is unrelated to the person's ability to perform the duties of nondiscrimination provision identical to this provision and binding upon any and all contractors and subcontractors. A breach of this covenant shall be regarded as a material breach of this contract.

25) **SUBCONTRACTING:** No subcontract work shall be started prior to the written approval of the subcontractor by the City. The City reserves the right to accept or reject any subcontractor.

26) **UNION COMPLIANCE:** Bidder agrees to comply with all regulations and requirements of any national or local union(s) that may have jurisdiction over any of the materials, facilities, services or personnel to be furnished by the City.

27) **WAIVER:** Failure of the City to insist upon strict compliance with any of the terms, covenants or conditions of this Agreement shall not be deemed a waiver of that term, covenant or condition or of any other term, covenant or condition. Any waiver or relinquishment of any right or power hereunder at any one or more times shall not be deemed a waiver or relinquishment of that right or power at any other time.

28) **CITY INCOME TAX WITHHOLDING:** Contractor and any subcontractor engaged in this contract shall withhold from each payment to his employees the City income tax on all of their compensation subject to tax, after giving effect to exemptions, as follows:

a) Residents of the City:

At a rate equal to 1% of all compensation paid to the employee who is a resident of the City of Flint.

b) Non-residents:

At a rate equal to 1/2% of the compensation paid to the employee for work done or services performed in the City of Flint.

These taxes shall be held in trust and paid over to the City of Flint in accordance with City ordinances and State law. Any failure to do so shall constitute a substantial and material breach of this contract.

29) **CONTRACT DOCUMENTS:** The invitation for proposal, instructions to proposal, proposal, affidavit, addenda (if any), statement of Bidder's qualifications (when required), general conditions, special conditions, performance bond, labor and material payment bond, insurance certificates, technical

specifications, and drawings, together with this agreement, form the contract, and they are as fully a part of the contract as if attached hereto or repeated herein.

30) **DISCLAIMER OF CONTRACTUAL RELATIONSHIP WITH SUBCONTRACTORS:** Nothing contained in the Contract Documents shall create any contractual relationship between the City and any Subcontractor or Sub-subcontractor.

31) **EFFECTIVE DATE:** Any agreement between the City and the Bidder shall be effective upon the date that it is executed by all parties hereto.

32) **FORCE MAJURE:** Neither party shall be responsible for damages or delays caused by Force Majeure nor other events beyond the control of the other party and which could not reasonably have anticipated the control of the other party and which could not reasonably have been anticipated or prevented. For purposes of this Agreement, Force Majeure includes, but is not limited to, adverse weather conditions, floods, epidemics, war, riot, strikes, lockouts, and other industrial disturbances; unknown site conditions, accidents, sabotage, fire, and acts of God. Should Force Majeure occur, the parties shall mutually agree on the terms and conditions upon which the services may continue.

**INDEMNIFICATION:** To the fullest extent permitted by law, Bidder agrees to defend, pay on behalf of, indemnify, and hold harmless the City of Flint, its elected and appointed officials, employees and volunteers and others working on behalf of the City of Flint, including the Project Manager, against any and all claims, demands, suits, or losses, including all costs connected therewith, and for any damages which may be asserted, claimed, or recovered against or from the City of Flint, its elected and appointed officials, employees, volunteers or others working on behalf of the City of Flint, by reason of personal injury, including bodily injury or death and/or property damage, including loss of use thereof, which may arise as a result of Bidder's acts, omissions, faults, and negligence or that of any of his employees, agents, and representatives in connection with the performance of this contract. Should the Bidder fail to indemnify the City in the above-mentioned circumstances, the City may exercise its option to deduct the cost that it incurs from the contract price forthwith. These provisions shall survive the termination or expiration of any agreement entered into as a result of this request.

33) **INDEPENDENT CONTRACTOR:** No provision of this contract shall be construed as creating an employer-employee relationship. It is hereby expressly understood and agreed that Bidder is an "independent contractor" as that phrase has been defined and interpreted by the courts of the State of Michigan and, as such, Bidder is not entitled to any benefits not otherwise specified herein.

34) **NO THIRD-PARTY BENEFICIARY:** No contractor, subcontractor, mechanic, material man, laborer, vendor, or other person dealing with the principal Contractor shall be, nor shall any of them be deemed to be, third-party beneficiaries of this contract, but each such person shall be deemed to have agreed (a) that they shall look to the principal Contractor as their sole source of recovery if not paid, and (b) except as otherwise agreed to by the principal Contractor and any such person in writing, they may not enter any claim or bring any such action against the City under any circumstances. Except as provided by law, or as otherwise agreed to in writing between the City and such person, each such person shall be deemed to have waived in writing all rights to seek redress from the City under any circumstances whatsoever.

- 35) **NON-ASSIGNABILITY:** Contractor shall not assign or transfer any interest in this contract without the prior written consent of the City provided, however, that claims for money due or to become due to Contractor from the City under this contract may be assigned to a bank, trust company, or other financial institution without such approval. Notice of any such assignment or transfer shall be furnished promptly to the City.
- 36) **NON-DISCLOSURE/CONFIDENTIALITY:** Contractor agrees that the documents identified herein as the contract documents are confidential information intended for the sole use of the City and that Contractor will not disclose any such information, or in any other way make such documents public, without the express written approval of the City or the order of the court of appropriate jurisdiction or as required by the laws of the State of Michigan.
- 37) **RECORDS PROPERTY OF CITY:** All documents, information, reports and the like prepared or generated by Contractor as a result of this contract shall become the sole property of the City of Flint.
- 38) **SEVERABILITY:** In the event that any provision contained herein shall be determined by a court or administrative tribunal to be contrary to a provision of state or federal law or to be unenforceable for any reason, then, to the extent necessary and possible to render the remainder of this Agreement enforceable, such provision may be modified or severed by such court or administrative tribunal so as to, as nearly as possible, carry out the intention of the parties hereto, considering the purpose of the entire Agreement in relation to such provision. The invalidation of one or more terms of this contract shall not affect the validity of the remaining terms.
- 39) **TERMINATION:** This contract may be terminated by either party hereto by submitting a notice of termination to the other party. Such notice shall be in writing and shall be effective 30 days from the date it is submitted unless otherwise agreed to by the parties hereto. Contractor, upon receiving such notice and prorated payment upon termination of this contract shall give to the City all pertinent records, data, and information created up to the date of termination to which the City, under the terms of this contract, is entitled.
- 40) **TIME PERFORMANCE:** Contractor's services shall commence immediately upon receipt of the notice to proceed and shall be carried out forthwith and without reasonable delay.
- 41) **EVALUATION OF PROPOSAL:** In the City's evaluation of proposals, at minimum: cost, serviceability, financial stability, and all requirements set forth in this document shall be considered as selection and award criteria unless otherwise specified.
- 42) **PREVAILING WAGE:** When applicable, all work for this project, including that of any subcontractor or sub-subcontractor, must meet Davis-Bacon Act requirements and full prevailing wage. Information on Davis-Bacon reporting and requirements, including payroll reporting, can be found at: <https://www.dol.gov/whd/govcontracts/dbra.htm>

- 43) INSURANCE & BONDS:** When applicable, the bidder whose proposal is accepted will be required to furnish bonds and evidence of insurance within five days from date of Notice of Award. In case of failure or refusal on the part of the bidder to furnish bonds, if required, within the set period, the amount of deposit may be forfeited to the county and the contract may be awarded to the next lowest responsible bidder. Upon the notification of award and approval of the bond, the deposit will be returned to the proposer. The deposit of persons other than the one to whom and award is made will be returned to the person or persons making the proposal immediately after the contract and bonds have been executed.
- 44) PROPOSAL SUBMISSION:** Proposals and all information requested of the vendor shall be entered in the appropriate spaces. Failure to do so may disqualify the vendor's offer. An authorized officer or employee of the bidder shall submit the proposal.
- 45) PRICES:** Prices proposed shall be for new products in current production unless otherwise specified. Where refurbished or discontinued items are offered they must be clearly identified as such. Prices proposed shall be exclusive of any rebates due the City. Any rebates the City may be entitled to should be shown as a separate line item and include expiration date.
- Corrections and/or modifications received after the bid closing time specified will not be accepted. Unit prices prevail.
- All prices will be bid F.O.B. DESTINATION, INCLUDE ALL DELIVERY AND ANY ADDITIONAL CHARGES, and remain in effect as specified in the quotation.
- 46) AWARD:** Unless otherwise stated in the proposal documents, the City cannot guarantee exclusivity of the contract for the proposed products or services.
- Award of the proposal shall be based upon a combination of factors, including but not limited to, adherence to proposal requirements, references and any other factors that may be in the City's best interest.
- The City reserves the right to reject any and all bids, and to waive any defect or irregularity in bids. The City reserves the right to accept and separate items in the bid;
- and to accept the proposal that in the opinion of the City is to the best advantage and interest of the public we serve. The City also has the right to re-solicit bids if it is deemed to be in the best interest of the City.
- The City reserves the right to reject low bids which have major deviations from our specification; to accept a higher quotation which has only minor deviations. By signing the bid, the vendor agrees to accept a split award unless the awarded vendor clearly indicates that it takes exception. The bid will be awarded to that responsible, responsive bidder whose proposal conforms to this solicitation, and will be most advantageous to the City, with regard not only to price, but also to availability of product, location and quality of product considered.
- The City reserves the right to award all line items, to make no award or to award on an individual line item basis, whichever is deemed to be in the best interest of the City.
- Time of delivery may be a consideration in the award.

**CITY OF FLINT PROPOSAL NO.21000604**

**LIFT STATION PUMPS**

**THE FOLLOWING PAGES MUST BE COMPLETED AND INCLUDED WITH SUBMITTAL IN THE FOLLOWING ORDER.**

**Purchasing Checklist:**

- Cover Sheet
- Exhibit A – Bid Form Submittal
- Exhibit B – List of References
- Exhibit C – Certificate of Insurance
- Exhibit D - Non-Bidder's Response
- City of Flint, Michigan Affidavit

## **LIFT STATION PUMPS**

### **PROJECT SCOPE**

The City of Flint Water Pollution Control (herein referred to as WPC) is seeking qualified manufactures to furnish and deliver, ready for installation, four (4) submersible style lift station pumps and four (4) Run Controllers. Equipment shall meet the design requirements below. WPC shall have the final decision on all equipment and recommendations.

### **BID SUBMITTALS**

Lift Station #2: Existing pumps Quantity (2) To replace the following: Worthington mdl 8FNV-16, Size 8 x 10, 2300 GPM, size 8x10, 40 HP. TDH low 21' High 43'. 480V 3 phase.

Lift Station #9: Existing pumps Quantity (2) To replace the following: Fairbanks Morse mdl 5445, size 10", 3200 GPM, 50 HP. TDH 40' at 3200GPM. 480V 3 phase. RPM 720.

Manufactures shall include with their bid a drawing that details the size of the pump and shows how it matches the current pumping system.

If piping modifications are required, the manufacturer must submit with their bid a sketch of the required changes.

Manufactures shall include all details of the pump they are providing include motor size, power requirements, pump curve and VFD specifications.

Approved manufactures are:

1. Flygt NT 3202 submersible drypit with partial stand.
2. Approved equal
  - A. Manufacturers requesting to be selected as an approved equal will submit certified documentation showing compliance with these specifications a minimum of three (3) days prior to bid opening. Failure to submit proper documentation or to adhere to the three (3) days prior timeline will result in bid disqualification.
  - B. Selected equipment manufacturers will be added to the list of approved manufacturers.

Failure to provide the information requested as mentioned above in this specification in the bid submittal shall result in bid disqualification.

## GENERAL

The pump(s) shall be heavy duty, electric submersible, centrifugal non-clog or chopper type units designed for handling raw, unscreened sewage, wipes, rags and wastewater and shall be fully guaranteed for this use. The pumps provided shall be capable of operating in an ambient liquid temperature of 104 degrees F. Since the high temperature of 104 degrees F is specified by the National Electrical Manufacturers Association (NEMA) and Factory Mutual (FM), motors with a maximum ambient temperature rating below 104 degrees F shall not be acceptable.

The pump and motor unit shall be suitable for continuous operation at full nameplate load while the motor is completely submerged, partially submerged or totally non-submerged. The use of shower systems, secondary pumps or cooling fans to cool the motor shall not be acceptable.

The pump, mechanical seals and motor units provided under this specification shall be from the same manufacturer in order to achieve standardization of operation, maintenance, spare parts, manufacturer's service and warranty.

## TESTING

Testing performed upon each pump shall include the following inspections:

- a. Impeller, motor rating and electrical connections shall be checked for compliance with this specification.
- b. Prior to submergence, each pump shall be run dry to establish correct rotation.
- c. Each pump shall be run submerged in water.
- d. Motor and cable insulation shall be tested for moisture content or insulation defects.

A written quality assurance record confirming the above testing/inspections shall be supplied with each pump for approval at the time of shipment.

Each pump shall be tested in accordance with the latest test code of the Hydraulic Institute (H.I.) to determine head vs. capacity and kilowatt draw required. The pump(s) shall be rejected if the above requirements are not satisfied.

## PUMP CONSTRUCTION

Major pump components shall be of grey cast iron, ASTM A-48, Class 35B, with smooth surfaces devoid of blow holes or other irregularities. The lifting handle shall be of stainless steel. All exposed nuts or bolts shall be of stainless steel construction. All metal surfaces coming into contact with the pumpage, other than stainless steel or brass, shall be protected by a factory applied spray coating of acrylic dispersion zinc phosphate primer with a polyester resin paint finish on the exterior of the pump.

Sealing design shall incorporate metal-to-metal contact between machined surfaces. Critical mating surfaces where watertight sealing is required shall be machined and fitted with Nitrile O-rings. Fittings will be the result of controlled compression of rubber O-rings in two planes and O-ring contact of four sides without the requirement of a specific torque limit.

Rectangular cross sectioned gaskets requiring specific torque limits to achieve compression shall not be considered as adequate or equal. No secondary sealing compounds, elliptical O-rings, grease or other devices shall be used.

Each unit shall be provided with an integral motor cooling system above 10 hp. A stainless steel motor cooling jacket shall encircle the stator housing, providing for dissipation of motor heat regardless of the type of pump installation. An impeller, integral to the cooling system and driven by the pump shaft, shall provide the necessary circulation of the cooling liquid through the jacket. The cooling liquid shall pass about the stator housing in the closed loop system in turbulent flow providing for superior heat transfer. The cooling system shall have one fill port and one drain port integral to the cooling jacket. The cooling system shall provide for continuous pump operation in liquid or ambient temperatures of up to 104°F (40°C). Operational restrictions at temperatures below 104°F are not acceptable. Fans, blowers or auxiliary cooling systems that are mounted external to the pump motor are not acceptable.

#### CABLE ENTRY SEAL

The cable entry seal design shall preclude specific torque requirements to insure a watertight and submersible seal. The cable entry shall consist of dual cylindrical elastomer grommets, flanked by washers, all having a close tolerance fit against the cable outside diameter and the entry inside diameter. The grommets shall be compressed by the cable entry unit, thus providing a strain relief function. The assembly shall provide ease of changing the cable when necessary using the same entry seal. The cable entry junction chamber and motor shall be sealed from each other, which shall isolate the stator housing from foreign material gaining access through the pump top. Epoxies, silicones, or other secondary sealing systems shall not be considered equal.

#### EXPLOSION PROOF MOTOR CLASS 1, DIVISION 1

The pump motor shall be a NEMA B design, induction type with a squirrel cage rotor, shell type design, housed in an air filled, watertight chamber. The stator windings shall be insulated with moisture resistant Class H insulation rated for 180°C (356°F). The stator shall be insulated by the trickle impregnation method using Class H monomer-free polyester resin resulting in a winding fill factor of at least 95%. The motor shall be inverter duty rated in accordance with NEMA MG1, Part 31. The stator shall be heat-shrink fitted into the cast iron stator housing. The use of multiple step dip and bake-type stator insulation process is not acceptable. The use of pins, bolts, screws or other fastening

devices used to locate or hold the stator and that penetrate the stator housing are not acceptable. The motor shall be designed for continuous duty while handling pumped media of up to 104°F. The motor shall be capable of no less than 30 evenly spaced starts per hour. The rotor bars and short circuit rings shall be made of aluminum. Three thermal switches shall be embedded in the stator end coils, one per phase winding, to monitor the stator temperature. These thermal switches shall be used in conjunction with and supplemental to external motor overload protection and shall be connected to the motor control panel.

The junction chamber shall be sealed off from the stator housing and shall contain a terminal board for connection of power and pilot sensor cables using threaded compression type terminals. The use of wire nuts or crimp-type connectors is not acceptable. The motor and the pump shall be produced by the same manufacturer.

The motor service factor (combined effect of voltage, frequency and specific gravity) shall be 1.15. The motor shall have a voltage tolerance of +/- 10%. The motor shall be designed for continuous operation in up to a 40°C ambient and shall have a NEMA Class B maximum operating temperature rise of 80°C. A motor performance chart shall be provided upon request exhibiting curves for motor torque, current, power factor, input/output kW and efficiency. The chart shall also include data on motor starting and no-load characteristics.

Motor horsepower shall be sufficient so that the pump is non-overloading throughout its entire performance curve, from shut-off to run-out. The motor and cable shall be capable of continuous submergence underwater without loss of watertight integrity to a depth of 65 feet or greater.

#### POWER/SENSOR CABLE

The power cable shall be sized according to the NEC and ICEA standards and shall be of sufficient length to reach the junction box without the need of any splices. The power cable shall be of a shielded design (if required to prevent interference with controls) in which an overall tinned copper shield is included and each individual phase conductor is shielded with an aluminum coated foil wrap. The outer jacket of the cable shall be oil resistant chlorinated polyethylene rubber. The cable shall be capable of continuous submergence underwater without loss of watertight integrity to a depth of 65 feet or greater. The manufacture is responsible to determine cable compliance with variable frequency drives provided in the control panel. If non-shielded cables are provided and interference is present, the manufacture is responsible to provide parts and labor to change to shielded cable at no cost to the Owner.

#### BEARINGS

The integral pump/motor shaft shall rotate on two bearings. The motor bearings shall be sealed and permanently grease lubricated with high temperature grease. The upper motor bearing shall be a two row angular contact ball bearing to handle radial loads. The lower bearing shall be a two row angular contact ball bearing to handle the thrust and radial forces. The minimum L10 bearing life shall be 50,000 hours at any usable portion of the pump curve.

#### MECHANICAL SEALS

Each pump shall be provided with a positively driven dual, tandem mechanical shaft seal system consisting of two seal sets, each having an independent spring. The lower primary seal, located between the pump and seal chamber, shall contain one stationary and one positively driven rotating corrosion and abrasion resistant tungsten-carbide ring. The upper secondary seal, located between the seal chamber and the seal inspection chamber shall be a leakage-free seal. The upper seal shall contain one stationary and one positively driven rotating corrosion and abrasion resistant tungsten-carbide seal ring. The rotating seal ring shall have small back-swept grooves laser inscribed upon its face to act as a pump as it rotates, returning any fluid that should enter the dry motor chamber back into the lubricant chamber. All seal rings shall be individual solid sintered rings. Each seal interface shall be held in place by its own spring system. The seals shall not depend upon direction of rotation for sealing. Mounting of the lower seal on the impeller hub is not acceptable.

Shaft seals without positively driven rotating members or conventional double mechanical seals containing either a common single or double spring acting between the upper and lower seal faces are not acceptable. The seal springs shall be isolated from the pumped media to prevent materials from packing around them, limiting their performance.

Each pump shall be provided with a lubricant chamber for the shaft sealing system. The lubricant chamber shall be designed to prevent overfilling and shall provide capacity for lubricant expansion. The seal lubricant chamber shall have one drain and one inspection plug that are accessible from the exterior of the motor unit. The seal system shall not rely upon the pumped media for lubrication.

The area about the exterior of the lower mechanical seal in the cast iron housing shall have cast in an integral concentric spiral groove. This groove shall protect the seals by causing abrasive particulate entering the seal cavity to be forced out away from the seal due to centrifugal action.

A separate seal leakage chamber shall be provided so that any leakage that may occur past the upper, secondary mechanical seal will be captured prior to entry into the motor stator housing. Such seal leakage shall not contaminate the motor lower bearing. The leakage chamber shall be equipped with a float type switch that will signal if the chamber should reach 50% capacity.

#### PUMP SHAFT

The pump and motor shaft shall be a single piece unit. The pump shaft is an extension of the motor shaft. Shafts using mechanical couplings shall not be acceptable. The shaft shall be stainless steel – ASTM A479 S43100-T. Shaft sleeves will not be acceptable.

#### IMPELLER

Due to the likely presence of sand and or grit the impeller shall be of Hard-Iron™ ASTM A-532 Alloy III A 25% chrome cast iron, dynamically balanced, semi-open, multi-vane, back swept, screw-shaped, non-clog design. The impeller leading edges shall be mechanically self-cleaned automatically upon each rotation as they pass across a spiral groove located on the volute suction. The leading edges of the impeller shall be hardened to RC 60 and shall be capable of handling solids, fibrous materials, heavy sludge and other matter normally found in wastewater. The screw shape of the impeller inlet shall provide an inducing effect for the handling of up to 5% sludge and rag-laden wastewater. The impeller to volute clearance shall be readily adjustable by the means of a single trim screw. The impeller shall be locked to the shaft, held by an impeller bolt and shall be coated with alkyd resin primer.

#### VOLUTE / SUCTION COVER

The pump volute shall be a single piece gray cast iron, ASTM A-48, Class 35B, non-concentric design with smooth passages of sufficient size to pass any solids that may enter the impeller. Minimum inlet and discharge size shall be as specified. The volute shall have a replaceable suction cover insert ring in which are cast spiral-shaped, sharp-edged groove(s). The spiral groove(s) shall provide trash release pathways and sharp edge(s) across which each impeller vane leading edge shall cross during rotation so to remain unobstructed. Due to the likely presence or sand or grit the insert ring shall be cast of Hard-Iron™ (ASTM A-532 Alloy III A 25% chrome cast iron) and provide effective sealing between the multi-vane semi-open impeller and the volute housing.

#### PROTECTION

Each pump motor stator shall incorporate three thermal switches, one per stator phase winding and be connected in series, to monitor the temperature of the motor. Should the thermal switches open, the motor shall stop and activate an alarm. A float switch shall be installed in the seal leakage chamber and will activate if leakage into the chamber reaches 50% chamber capacity, signaling the need to schedule an inspection.

The thermal switches and float switch shall be connected to a Mini CAS control and status monitoring unit. The Mini CAS unit shall be designed to be mounted in the pump control panel.

#### CLOG-FREE GUARANTEE

The manufacture shall guarantee clog-free operation for a period of 12 months from the date of start-up of the pumps by the local authorized factory representative. A certificate shall be provided to the Owner on the day of start up with the local contact information and effective date. Should the impeller clog with typical solids and/or modern trash debris normally found in domestic wastewater during this period, an authorized representative shall either travel to the jobsite remove the pump, clear the obstruction and reinstall the pump at no cost or reimburse the Owner for reasonable cost to provide this service. A written report shall be provided to the Owner detailing the service call with pictures for verification purposes.

## START-UP SERVICE

A factory authorized start up technician with a minimum of 5 years experience shall be provided to visit the site for a minimum of 8 hours on-site and confirm pump/s and controls operation meets or exceeds the specifications. The name of the technician along with the qualifications shall be submitted prior to start up upon Engineer/Owner request. The service technician shall be outfitted with a service crane truck capable of pulling the pumps to verify rotation and perform a visual check of the pump/s along with the following items at a minimum:

- a. Megger stator and power cables.
- b. Inspect pump/s cables for damage.
- c. Verify proper base and rail installation.
- d. Check seal lubrication.
- e. Check for proper rotation.
- f. Check power supply voltage.
- g. Measure motor operating amperage load and no load amperage.
- h. Perform shut of head test and draw down flow test.
- i. Check level control operation, sequence and alarm call out of telemetry.

The factory start up form shall be submitted for approval prior to start up and approved by the Owner. The Owner, at their discretion, may add items to be completed at start up that they feel proves compliance with all project requirement and will notify the Contractor of these items prior to start up. During this initial inspection, the manufacturer's service representative shall review recommended operation and maintenance procedures with the Owner's personnel. The Owner shall be provided with (1) additional training day that can be used at no cost to the Owner within the first year of startup. This 8-hour training day is to allow time for the Owners personnel to utilize the equipment and become familiar with the operation.

## VFD

The manufacturer shall provide two SmartRun VFDs sized properly to run the manufacturers selected pump and meeting the following capabilities:

freeing debris and unclogging blockages when needed, setting the optimal speed for energy efficiency and cost savings, as well as communicating with external monitoring equipment.

SmartRun takes care of pump cleaning, pipe cleaning, sump cleaning, soft starts and stops.

## WARRANTY

The pump/s shall be provided with a NON-PRORATED 100% 5-year warranty against defects in materials and or workmanship. The warranty shall cover the entire pump not individual components. Upon warranty occurrence the manufacture/manufactures authorized service center shall remove the pump, repair, reinstall and provide start up on the repaired pump. In the event that the repair cannot be done within 4 weeks of removal a loaner pump shall be provided within 1 week to the Owner until such time that the repaired pump can be returned. Installation of the loaner pump and removal shall be provided by the manufacture/manufactures representative. Upon request from the Owner the pump supplier shall provide a warranty bond covering the above requirements.

Provide a 3"x5" stainless steel plate stamped or engraved with the following information and affix to the control panel inner door, MCC or as directed by the Owner:

- Pump manufacturer, model and serial number
- Duty point GPM & TDH
- Phase, voltage, HP & RPM
- Cable length
- Warranty and clog free guarantee start and end date
- Manufacture/manufactures authorized service center name and contact phone number

A detailed start-up report shall be submitted to the Owner along with a detailed failure analysis.

**EXHIBIT A**

**LIFT STATION PUMPS  
BID SUBMITTAL FORM**

Quantity	U/M	Description	Unit Price	Amount
2	Each	Lift Station #2 Drypit Submersible Style Pump with Smart Run VFD		
2	Each	Lift Station #9 Drypit Submersible Style Pump with Smart Run VFD		
			<b>TOTAL</b>	<b>\$</b>

1. Failure to use this bid form shall result in bid disqualification.
2. Failure to bid on all items shall result in an "incomplete bid" determination.
3. List value-added considerations on a separate sheet of paper.

Terms: \_\_\_\_\_ Fed. ID#: \_\_\_\_\_

Firm Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Signed: \_\_\_\_\_ Date: \_\_\_\_\_

**EXHIBIT B**

**LIFT STATION PUMPS**

**LIST OF REFERENCES: (3) SIMILAR SCOPE OF WORK FROM THE LAST 5 YEARS**

Providing the following contact information enables the City of Flint to contact those accounts as references.

**Reference #1:**

Company/Municipality: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Title: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

Type of Project: \_\_\_\_\_

\_\_\_\_\_

Project Timeline (Dates): \_\_\_\_\_ Budget: \_\_\_\_\_

**Reference #2:**

Company/Municipality: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Title: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

Type of Project: \_\_\_\_\_

\_\_\_\_\_

Project Timeline (Dates): \_\_\_\_\_ Budget: \_\_\_\_\_

**EXHIBIT B**

**LIFT STATION PUMPS**

**LIST OF REFERENCES: (3) SIMILAR SCOPE OF WORK FROM THE LAST 5 YEARS (continues)**

**Reference #3:**

Company/Municipality: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Title: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

Type of Project: \_\_\_\_\_

Project Timeline (Dates): \_\_\_\_\_ Budget: \_\_\_\_\_

## **EXHIBIT C**

### **LIFT STATION PUMPS CERTIFICATE OF INSURANCE**

#### **INSURANCE REQUIREMENTS**

The Contractor shall notify all insurance agents and companies retained by the Contractor that these insurance requirements shall be included in any Agreement between the Contractor and the City of Flint.

The Contractor shall purchase and maintain, at its sole expense and as long as it is providing services to the City, the following insurance coverage:

Commercial General Liability - Occurrence form, including coverage for bodily injury, personal injury, property damage (broad form), premises/operations, blanket contractual, and products/completed operations. Coverage shall be endorsed to include the City as an additional insured for work performed by the Contractor in accordance with the Agreement.

#### **Minimum Limits:**

- \$1,000,000 per occurrence/\$2,000,000 general aggregate
- \$2,000,000 aggregate for products and completed operations
- \$1,000,000 personal and advertising injury

Automobile - Michigan "no-fault" coverage, and residual automobile liability, comprehensive form, covering owned, hired, and non-owned automobiles. Coverage shall be endorsed to include the City as an additional insured for work performed by the Contractor in accordance with the Agreement.

#### **Minimum Limits:**

- No-fault coverages - statutory
- \$500,000 per person/\$1,000,000 per accident - bodily injury
- \$500,000 per occurrence - property damage
- A combined single limit of \$1,000,000 per occurrence

Workers' Compensation and Employer's Liability- Statutory coverage or proof acceptable to the City of approval as a self-insurer by the State of Michigan.

## EXHIBIT C

### LIFT STATION PUMPS CERTIFICATE OF INSURANCE (continues)

#### Minimum Limits:

- Workers' Compensation - statutory
- Employer's Liability - \$100,000 each accident/\$100,000 disease - each employee
- \$500,000 disease - policy limit

Professional Liability – Covering acts, errors or omissions of a professional nature committed or alleged to have been committed by the Contractor or any of its subcontractors. Coverage shall be effective upon the date of the Agreement and shall remain effective for a period of three (3) years after the date of final payment thereunder. Such coverage shall be endorsed to include any subcontractors hired by the City.

#### Minimum Limits:

- \$1,000,000 per occurrence, \$1,000,000 annual aggregate

Insurance coverage shall cover all claims against the City of Flint, its officials and employees, arising out of the work performed by the Contractor or any subcontractors under the Agreement. Should any work be subcontracted, it shall be the responsibility of the Contractor to maintain Independent Contractor's Protective Liability Insurance with limits equal to those specified above for Commercial General Liability Insurance. In addition, the Contractor shall provide proof of Workers' Compensation Insurance for all subcontractors in compliance with the required statutory limits of the State of Michigan.

Said policies of insurance shall be with companies licensed to do business in the State of Michigan and in a form satisfactory to the City. All insurance companies must maintain a rating of B+, VIII or better from AM. Best Company. Certificates of insurance with a thirty-(30) day cancellation clause shall be filed with and approved by the City at least five (5) days in advance of commencing work under the Agreement. Cancellation, material restriction, non-renewal or lapse of any of the required policies shall be grounds for immediate termination of the Agreement by the City.

The City reserves the right to request a complete certified copy of the policies for the above coverage's.

Any reduction or exhaustion in the limits of required insurance coverage shall not be deemed to limit the indemnification afforded in accordance with the Agreement or any amendments thereto.

Depending on the subject matter of the transaction, the City may require other insurance coverage in addition to the coverage's contained herein.

**THE BID NUMBER IS TO APPEAR ON ALL INSURANCE CERTIFICATES**

**EXHIBIT D**

**LIFT STATION PUMPS  
NON-BIDDER'S RESPONSE**

**VENDORS NAME:** \_\_\_\_\_

For the purpose of facilitating your firm's response to our invitation to bid, the City of Flint is interested in ascertaining reasons for prospective bidder's failure to respond to "Invitations to Bid". If your firm is not responding to this bid, please indicate the reason(s) by checking any appropriate item(s) below and return this form to the above address.

We are *not* responding to this "Invitation to Bid" for the following reason(s):

\_\_\_\_\_ Items or materials requested not manufactured by us or not available to our company.

\_\_\_\_\_ Our items and/or materials do not meet specifications.

\_\_\_\_\_ Specifications not clearly understood or applicable (too vague, too rigid, etc.).

\_\_\_\_\_ Quantities too Small.

\_\_\_\_\_ Insufficient time allowed for preparation of bid.

\_\_\_\_\_ Incorrect address used. Our correct mailing address is: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_ Our branch / division handles this type of bid. We have forwarded this bid on to them but for the future the correct name and mailing address is: \_\_\_\_\_

\_\_\_\_\_ **OTHER:** \_\_\_\_\_

\_\_\_\_\_

**Thank you for your participation in this bid.**

**CITY OF FLINT, MICHIGAN AFFIDAVIT**

**AFFIDAVIT FOR INDIVIDUAL**

STATE OF \_\_\_\_\_

S.S.

COUNTY OF \_\_\_\_\_

\_\_\_\_\_ being duly sworn,  
deposes and says that they are the person making the above bid; and that said bid is genuine and not sham or collusive, and is not made in the interest of or on behalf of any person not therein named, and that they have not directly or indirectly induced or solicited any bidder to put in a sham bid; that they have not directly or indirectly induced or solicited any other person or corporation to refrain from bidding, and that they have not in any manner sought by collusion to secure themselves any advantage over other bidders.

Subscribed and sworn to before me at \_\_\_\_\_, in said County and State,

this \_\_\_\_\_ day of \_\_\_\_\_, A.D. 20 \_\_\_\_\_,

\_\_\_\_\_  
\*Notary Public, \_\_\_\_\_ County, \_\_\_\_\_

My Commission expires \_\_\_\_\_, 20 \_\_\_\_\_

*NOTE: If executed outside of the State of Michigan, certificate by the Clerk of the Court of Record, authenticating the Notary's Signature and authority should be attached.*

**FOR CORPORATION**

STATE OF \_\_\_\_\_

S.S.

COUNTY OF \_\_\_\_\_

\_\_\_\_\_ being duly sworn, deposes and says that she/he/they  
is \_\_\_\_\_ of \_\_\_\_\_

(Official Title)

(Name of Corporation)

a corporation duly organized and doing business under the laws of the State of \_\_\_\_\_  
the corporation making the within and foregoing bid; that they executed said bid in behalf of said corporation by  
authority of its Board of Directors; that said bid is genuine and not sham or collusive and is not made in the  
interests of or on behalf of any person not herein named, and that they have not and said bidder has not directly  
or indirectly induced or solicited any other person or corporation to refrain from bidding; that they have not and  
said bidder has not in any manner sought by collusion to secure to themselves or to said corporation an advantage  
over other bidders.

Subscribed and sworn to before me at \_\_\_\_\_, in said County and State,  
this \_\_\_\_\_ day of \_\_\_\_\_, A.D. 20\_\_\_\_,

\_\_\_\_\_  
\*Notary Public, \_\_\_\_\_ County, \_\_\_\_\_

My Commission expires \_\_\_\_\_, 20\_\_\_\_

**NOTE: If executed outside of the State of Michigan, certificate by the Clerk of the Court of Record, authenticating the Notary's Signature and authority should be attached.**

**FOR PARTNERSHIP**

STATE OF \_\_\_\_\_

S.S.

COUNTY OF \_\_\_\_\_

\_\_\_\_\_ being duly sworn,  
deposes and says that they are a member of the firm of \_\_\_\_\_, a co-  
partnership, making the above bid; that they are duly authorized to make said bid on behalf of said co-partnership;  
that said bid is genuine and not sham or collusive, and is not made in the interest of or on behalf of any person not  
therein named, and that they have and said bidder has not directly or indirectly induced or solicited any other  
person or corporation to refrain from bidding, and that they have not and said bidder has not in any manner  
sought by collusion to secure to themselves or to said bidder any advantage over other bidders.

Subscribed and sworn to before me at \_\_\_\_\_, in said County and State,

this \_\_\_\_\_ day of \_\_\_\_\_, A.D. 20\_\_\_\_\_,

\_\_\_\_\_  
\*Notary Public, \_\_\_\_\_ County, \_\_\_\_\_

My Commission expires \_\_\_\_\_, 20\_\_\_\_\_

*NOTE: If executed outside of the State of Michigan, certificate by the Clerk of the Court of Record, authenticating the Notary's Signature and authority should be attached.*

**FOR AGENT**

STATE OF \_\_\_\_\_

S.S.

COUNTY OF \_\_\_\_\_

\_\_\_\_\_ being duly sworn, deposes and says that they executed the within and foregoing bid in behalf of \_\_\_\_\_ the bidder therein named, they having been theretofore lawfully authorized, as the agent of said bidder, so to do; that said bid is genuine and not sham or collusive and not made in the interests of or on behalf of any person not therein named, and that they have not and said bidder has not directly or indirectly induced or solicited any bidder to put in a sham bid; that they have not and said bidder has not directly or indirectly induced or solicited any other person or corporation to refrain from bidding, and that they have not and said bidder has not in any manner sought by collusion to secure to themselves or to said bidder any advantage over other bidders.

Subscribed and sworn to before me at \_\_\_\_\_, in said County and State, this \_\_\_\_\_ day of \_\_\_\_\_, A.D. 20\_\_\_\_,

\_\_\_\_\_  
\*Notary Public, \_\_\_\_\_ County, \_\_\_\_\_

My Commission expires \_\_\_\_\_, 20\_\_\_\_

*NOTE: If executed outside of the State of Michigan, certificate by the Clerk of the Court of Record, authenticating the Notary's Signature and authority should be attached.*