



# City of Flint

## Department of Purchases & Supplies

---

Sheldon A. Neeley

TO: All Proposers  
FROM: Jennifer Ryan  
Deputy Finance Director  
DATE: **May 12, 2021**  
SUBJECT: **Addendum #02** – Proposal# 22000703 – Cleanout of East Sludge Tank

This addendum has been issued because of the following:

1. **Attached are Questions and Answers**
2. **Listed below is the Google Meet information for the bid opening date – Tuesday, May 18, 2021 at 11:00 a.m.**

**Join with Google Meet**

[meet.google.com/muv-koon-bnj](https://meet.google.com/muv-koon-bnj)

**Meeting ID**

[meet.google.com/muv-koon-bnj](https://meet.google.com/muv-koon-bnj)

**Phone Numbers**

**(US)+1 617-675-4444**

**PIN: 325 251 761 3705#**

All other bidding terms, requirements, and conditions continue as indicated in the remaining original bid documents.

The Deputy Finance Director, Jennifer Ryan, is an officer for the City of Flint with respect to this RFP.

**In the submission of their proposal, Proposer must acknowledge receipt of this addendum. Proposer shall acknowledge this addendum by signing and returning one copy of this notice with their submission.**

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City / State / Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Thank you.

Jennifer Ryan  
Deputy Finance Director



QUESTIONS RECEIVED IN THE DIVISION OF PURCHASES & SUPPLIES  
For Cleanout of East Sludge Tank  
PROPOSAL# 22000703

1. Are prevailing wages / Davis Bacon or any other special employee wage/benefit requirements applicable?  
**No.**
2. Are any bonds required? If so, what type?  
**A bond is not required.**
3. Can contractors work onsite 7:00 am – 9:00 pm M-F?  
**If they call ahead and setup a walk through.**
4. Will the City provide high pressure hydrant water for cleaning/dilution at no cost to the contractor?  
**We have water available. Both portable and non-portable. Not sure how much pressure they need but it worked for the last company who performed this work.**
5. If requested, can the City provide 480V 3 phase electrical power 100 + amps (even if a portable generator) at no cost to the contractor?  
**Yes.**
6. Is your estimate of 600 cubic yards to remove still valid?  
**As far as we can estimate - yes.**
7. What is the address where the tank is located?  
**The Address is G-4652 Beecher Rd Flint, MI 48532.**
8. Can you please provide a schematic of the tank?  
**Attached are two drawings of the tank. The tank is 80ft diameter, 29ft side walls with a 7.5ft cone at the bottom of the tank.**



