## CITY OF FLINT- RENTAL HOUSING INSPECTION CHECKLIST – FOR REFERENCE ONLY

SMOKE Detectors:	WINDOWS:
☐ Properly installed and operable	☐ Proper location and sizes for light and ventilation
☐ Installed in correct locations: In sleeping units, outside of sleeping	☐ Proper for egress and lockable
units, and on every floor	☐ Snug fit, openable and not broken or cracked
FURNACE:	☐ Screens installed between June 1 and October 15
☐ Gas shut off valve and on/off switch	☐ Egress windows for basement bedrooms
☐ Vent secured and properly pitched	$\ \square$ Bathrooms have operable window with screen (June 1-Oct. 15) or a
☐ Filters are replaced/cleaned regularly	vent fan
☐ Operable, provides minimum 68 degrees	DOORS:
☐ Adequate surrounding clearance	☐ Bedrooms and bathrooms require privacy doors
WATER HEATER:	☐ Bedroom doors – no padlocks or inside keyed
☐ Gas shut off valve	☐ Exterior doors – correct for egress and lockable
☐ Proper pop-off valve and drop line	☐ Exterior doors – snug fit, operable and unbroken
☐ Vent secured and properly pitched	ROOMS:
☐ Operable with no rust holes or leaks	$\ \square$ Walls, floors, and ceilings intact and maintained
☐ Adequate surrounding clearance	$\square$ Unobstructed egress within and out of home
ELECTRICAL PANEL	☐ Proper square footage, ceiling height and layout
☐ Service amps adequate for usage	$\square$ Fireplaces, wood stoves operable and maintained
☐ Properly grounded and in good condition	$\square$ No rubbish or garbage accumulation, infestations
☐ No open circuits in box	☐ Basement bedrooms comply with all safety codes
☐ All circuits labeled and readable	STAIRWAYS:
☐ If fuses – proper sizes	$\square$ Adequately lighted, no stored items blocking egress
Adequate clearance and easy access	☐ Steps stable, unbroken and adequate strength
GENRAL ELECTRICAL:	☐ Handrails required if 5 or more steps
Covers on switches, junction boxes and outlets	☐ Guardrails on open stairs over 30" high
☐ Splices to code in covered boxes	BUILDING EXTERIOR:
☐ Wire in conduit where required	☐ Roof waterproof and maintained; gutters work
☐ GFCIs where required and operable	$\ \square$ Walls, foundation, and chimney maintained
☐ Switches, outlets, and fixtures operable	☐ Porches solid and maintained
☐ Minimum 2 outlets in all rooms, properly spaced	☐ No openings for animal infestations
☐ Adequate light fixtures, with globes as required	☐ Guardrails on porches or stairs over 30" high
☐ Buffer space between lights and combustibles	☐ Handrails required if 5 or more steps
☐ Safe, limited use of extension cords	☐ House numbers present and readable from street
☐ Exterior service lines secure and protected	GARAGE:
GENERAL PLUMBING:	☐ Proper electrical service, wiring, fixtures, etc.
☐ Installed correctly with no leaks	☐ Structure solid and maintained
□ Proper venting	YARD:
☐ Functioning drains with proper traps and covers	☐ Fences built to code and maintained
SINKS, BATHTUBS & SHOWERS:	$\square$ Grass, shrubs, and trees maintained to code
☐ Ventilation in bathroom	☐ Accessory buildings maintained to code
☐ Proper number and location	☐ Pools maintained and secure from child entry
☐ Operable, with hot and cold water	☐ Outdoor trash kept in solid covered container
☐ Functioning drains with proper traps	$\square$ No junk, trash, or building materials stored outside
□ No leaks or drips	☐ No inoperable vehicles or stored vehicle parts/tires
☐ Garbage disposal operable if present	☐ No improper vehicle, RV or trailer parking
TOILETS:	☐ No unsafe or unsanitary conditions
☐ Operating properly	☐ Pet waste must be removed regularly
☐ No overflow to sewer from tank	GENERAL:
☐ No leaks or continuous running	☐ Permits pulled for repairs or new work required
LAUNDRY:	
☐ Proper dryer vent to exterior with cover	Note: It is recommended that a fire extinguisher be provided for safety. $\label{eq:local_problem}$
☐ Gas shut off valve, end of line capped if unused	City of Flint rental inspections do not include inspections for mold,
☐ Proper and grounded electrical connection	airborne contaminants or other possible contaminants.
☐ Washtub faucet backflow prevention present	

Note: This is not a comprehensive list of all requirements. Questions? Please call the Building Department at (810) 766-7284