



City of Flint

Department of Purchases & Supplies

Sheldon A. Neeley

TO: All Proposers
FROM: Lauren Rowley, Purchasing Manager
DATE: **September 19, 2025**
SUBJECT: **Addendum #01 – P26000517: WPC SLUICE GATE REPAIR PROJECT**

This addendum has been issued to address the following Q&A:

1. ***Will the Contractor be required to submit an engineer-stamped rigging plan, or is a plan by a Qualified Person sufficient for the City's requirements?*** A qualified person is sufficient.
2. ***Do I understand correctly that proposals must be submitted electronically on MITN AND hard copy with original signature are to be received by 9/23 at 1100hrs? And if the hard copy is required in addition to the electronic submission, can it be delivered in-person or by courier to the Division of Purchases and Supplies?*** Yes, the City requires both Hard copies as outlined in the RFP AND electronic copies submitted through bidnet. (If you have technical difficulties submitting via bidnet, please email to purchasingbids@cityofflint.com) Hard copies can either be postal mailed to the address specified in the RFP, or hand delivered as long as they are received by the due date specified in the RFP.
3. ***Is there any restriction on hours available to work on site? Are extended shifts available? Weekends?*** The City has personnel onsite 24hrs/day. Longer hours are acceptable if pre approved.
4. ***In the event that work must proceed into "Phase II"***
 - a. ***Will bypass pumping be contracted by the City separate from this contract? If it is to be included in Phase II pricing, please provide bypass specifications. It will be contracted by the City separate from this contract***
 - b. ***Is there a "typical" number of times the gate is opened/ closed that should be taken into consideration for manual gate operation? If not, can unit pricing be provided for this, as the number of mobilizations cannot be anticipated?*** Once opened the gate will remain open. If the coupling works on phase 1 then the project will be completed. If it proceeds to phase 2 then the gate will have to be opened and secured one time while the others parts are procured. Once the parts arrived and the station is bypassed then the gate will have to be lowered and all parts can be installed.

All other bidding terms, requirements, and conditions continue as indicated in the remaining original bid documents.

The Purchasing Manager, Lauren Rowley, is an officer for the City of Flint with respect to this RFP.

In the submission of their proposal, Proposer must acknowledge receipt of this addendum. Proposer shall acknowledge this addendum by signing and returning one copy of this notice with their submission.

Company Name: _____

Address: _____



City of Flint

Department of Purchases & Supplies

City / State / Zip: _____

Telephone: _____ Fax: _____ Email: _____

Print Name: _____ Title: _____

Signature: _____ Date: _____

Thank you,

Lauren Rowley, Purchasing Manager