

Section 00 9113 Addendum No. 02

WPC Influent Structure and Battery A Grit Rehabilitation Project
Proposal No. 20000578
City of Flint, Michigan 48502

To all prospective bidders and others concerned, YOU ARE HEREBY ADVISED THAT the Contract Documents for the above referenced Project are revised in the following particulars:

<u>Section</u>	<u>Description of Change</u>
33 0132	In Section 33 0132, Article 2.01.A shall be revised as follows: A. Geopolymer lining system shall be "GeoSpray" as manufactured by Milliken Infrastructure Solutions, "GeoKrete" as manufactured by Quadex, or ENGINEER approved equal.
33 0132	In Section 33 0132, the table specified in Article 2.02.A shall be revised as follows: <ul style="list-style-type: none">• Minimum Flexural Strength shall be 800 psi;• Maximum Final Set shall be 240 minutes
40 0560	In Section 40 0560, Article 2.02.H shall be revised as follows: H. Manufacturer: Rodney Hunt, WHIPPS, or ENGINEER approved equal.
40 7100	In Section 40 7100, Article 2.01.F, the following sentence shall be added to the end of the Article: "...The flow transmitter shall have HART Communications."

This Addendum is hereby incorporated into the original Contract Documents for the bidding referred to above and is considered as binding as though originally appearing therein. RECEIPT OF THIS ADDENDUM MUST BE NOTED in the place provided on the Proposal page 00 4243-1 and dated **May 13, 2020**.