

CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT

SUPPLY NAME: CITY of FLINT WATER PLANT
WSSN: 2310

Michael Glasgow
 Operator-in-Charge

December 2014
 Month/Year

F-1R, F-2
 Certification of Operator-in-Charge

F-1
 Water Plant Classification

 Signature of Operator-in-Charge

Genesee
 County

Treatment Rate and Filter Data

Maximum Treatment Rate:	<u>23.8</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>74</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.4</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.2</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>2.9%</u>	Percent of Treated Water

Chemical Data

Chlorine on hand:	<u>20,000</u> lb.	Est. supply:	<u>30</u> days
Primary Coagulant (Ferric Chloride) on hand:	<u>54,000</u> lb.	Est. supply:	<u>18</u> days
Lime (CaO) on hand:	<u>296</u> tons	Est. supply:	<u>34</u> days
Fluoride on Hand:	<u>16,630</u> lb.	Est. supply:	<u>35</u> days
Cost of All Chemicals per Million Gallons:	<u>n/a</u> dollars		
Total Power Cost per Million Gallons:	<u>n/a</u> dollars		

Remarks

	Confluence Point # 1 (N)	Confluence Point # 2 (S)
Number of filter confluence samples > 0.3 NTU:	<u>0</u>	<u>0</u>
Number of filter confluence samples collected:	<u>232</u>	<u>232</u>
Percent of filter confluence samples > 0.3 NTU:	<u>0.0%</u>	<u>0.0%</u>
Number of filter confluence samples > 1 NTU	<u>0</u>	<u>0</u>
Did any individual filter exceed:		
1.0 NTU in two consecutive measurements taken 15 minutes apart?		<u>NO</u>
If yes , attach specific filter(s) information and indicate required follow-up status.		
0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?		<u>NO</u>
If yes , attach specific filter(s) information and indicate required follow-up status.		
1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?		<u>NO</u>
If yes , attach specific filter(s) information and indicate required follow-up status.		
2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?		<u>NO</u>
If yes , attach specific filter(s) information and indicate required follow-up status.		
Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?		<u>NO</u>
If yes , indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.		
Did POE disinfectant residual fall below 0.2 ppm during the month?		<u>NO</u>
If yes , indicate date(s) and duration on a separate sheet.		
Was minimum C*T credit achieved for the entire month?		<u>YES</u>
If no , indicate on a separate sheet the date(s) not achieved.		
Was continuous POE chlorine residual monitoring equipment off-line during the month?		<u>NO</u>
If yes , indicate date(s) and duration on a separate sheet.		

WSSN: 2310

Date	Turbidity, Units												Point of Entry Plant Tap NTU
	Confluence Point. No.1 (N) North						Confluence Point. No.2 (S) South						
	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	
1	8	0.09	0.11	6	0	0	8	0.09	0.10	6	0	0	0.09
2	8	0.08	0.09	6	0	0	8	0.08	0.09	6	0	0	0.08
3	8	0.08	0.12	6	0	0	8	0.07	0.10	6	0	0	0.07
4	8	0.07	0.10	6	0	0	8	0.07	0.08	6	0	0	0.07
5	8	0.07	0.08	6	0	0	8	0.07	0.09	6	0	0	0.08
6	8	0.10	0.12	6	0	0	8	0.10	0.10	6	0	0	0.08
7	0			0	0	0	0			0	0	0	0.07
8	0			0	0	0	0			0	0	0	0.12
9	8	0.09	0.19	6	0	0	8	0.07	0.11	6	0	0	0.08
10	8	0.08	0.14	6	0	0	8	0.06	0.07	6	0	0	0.05
11	8	0.08	0.10	6	0	0	8	0.07	0.10	6	0	0	0.07
12	8	0.09	0.13	6	0	0	8	0.09	0.14	6	0	0	0.07
13	8	0.07	0.10	6	0	0	8	0.07	0.08	6	0	0	0.08
14	8	0.06	0.07	6	0	0	8	0.06	0.07	6	0	0	0.05
15	8	0.06	0.06	6	0	0	8	0.06	0.07	6	0	0	0.06
16	8	0.07	0.08	6	0	0	8	0.06	0.06	6	0	0	0.06
17	8	0.07	0.08	6	0	0	8	0.07	0.08	6	0	0	0.08
18	8	0.07	0.11	6	0	0	8	0.06	0.07	6	0	0	0.07
19	8	0.08	0.13	6	0	0	8	0.06	0.09	6	0	0	0.07
20	8	0.07	0.10	6	0	0	8	0.07	0.09	6	0	0	0.06
21	8	0.06	0.07	6	0	0	8	0.06	0.09	6	0	0	0.07
22	8	0.06	0.07	6	0	0	8	0.07	0.16	6	0	0	0.06
23	8	0.07	0.09	6	0	0	8	0.07	0.12	6	0	0	0.07
24	8	0.06	0.10	6	0	0	8	0.06	0.10	6	0	0	0.06
25	8	0.06	0.09	6	0	0	8	0.06	0.10	6	0	0	0.06
26	8	0.08	0.16	6	0	0	8	0.07	0.15	6	0	0	0.08
27	8	0.08	0.12	6	0	0	8	0.07	0.11	6	0	0	0.07
28	8	0.07	0.11	6	0	0	8	0.05	0.07	6	0	0	0.07
29	8	0.07	0.09	6	0	0	8	0.06	0.07	6	0	0	0.08
30	8	0.06	0.08	6	0	0	8	0.05	0.06	6	0	0	0.06
31	8	0.07	0.09	6	0	0	8	0.06	0.08	6	0	0	0.08
Avg.	7	0.07	0.10	6	0	0	7	0.07	0.09	6	0	0	
Max.	8	0.10	0.19	6	0	0	8	0.10	0.16	6	0	0	0.12
Min.	0	0.06	0.06	0	0	0	0	0.05	0.06	0	0	0	

Date	Fluoride Applied as F-mg/L	Fluoride Analysis (mg/L)			Chlorine Application (mg/L)			Chlorine Residual (mg/L)					
					Intermediate Chlorine	Post Chlorine	Total Chlorine	Filtered		3 MG Well		Tap	
		Raw	Tap	Dist.				Free	Total	Free	Total	Free	Total
1	0.5	0.22	0.71		2.0	3.8	5.8	0.5	0.8	3.0	3.5	3.0	3.5
2	0.5	0.21	0.72		2.0	3.6	5.6	0.7	1.0	3.0	3.5	2.7	3.2
3	0.5	0.23	0.72		2.1	3.0	5.1	0.7	1.0	2.7	3.2	2.5	2.9
4	0.5	0.21	0.73	0.64	2.0	3.0	5.0	0.6	0.8	3.0	3.5	2.4	2.8
5	0.4	0.21	0.68		1.9	3.0	4.9	0.6	0.8	2.7	3.2	2.2	2.5
6	0.5	0.22	0.77		1.9	3.0	4.9	0.4	0.6	3.1	3.5	2.1	2.5
7		0.22	0.70				0.0			3.0	3.5	2.4	2.8
8		0.22	0.71				0.0			2.9	3.2	2.6	2.9
9	0.4	0.24	0.67	0.65	2.0	2.3	4.3	0.6	0.8	2.2	2.9	2.7	3.1
10	0.4	0.22	0.71		1.8	2.7	4.5	0.5	0.8	2.6	2.9	2.4	2.7
11	0.4	0.24	0.69		1.8	2.8	4.6	0.5	0.7	2.5	3.1	2.4	2.8
12	0.4	0.21	0.64		1.8	2.7	4.5	0.6	0.8	2.4	2.9	2.0	2.3
13	0.4	0.21	0.63		2.0	2.6	4.6	0.6	0.8	3.0	3.5	2.6	2.9
14	0.4	0.20	0.64		2.0	2.6	4.6	0.7	1.0	2.9	3.2	2.9	3.1
15	0.4	0.24	0.64		2.0	2.6	4.6	0.7	0.9	2.8	3.0	2.6	2.9
16	0.4	0.24	0.63	0.60	2.0	2.6	4.6	0.7	0.9	2.8	3.0	2.3	2.5
17	0.4	0.22	0.63		2.0	2.6	4.6	0.7	0.9	2.7	3.0	2.4	3.0
18	0.4	0.21	0.59		2.0	2.7	4.7	0.6	0.8	2.6	3.0	2.1	2.4
19	0.4	0.21	0.58		2.1	2.6	4.7	0.7	0.9	3.0	3.3	2.6	3.1
20	0.4	0.20	0.61		1.9	2.6	4.5	0.6	0.8	2.6	3.1	2.0	2.5
21	0.4	0.22	0.62		1.3	2.4	3.7	0.6	0.8	2.8	3.0	2.6	2.8
22	0.4	0.22	0.63		2.0	2.6	4.6	0.9	1.1	2.7	3.1	2.6	3.0
23	0.4	0.23	0.63	0.64	1.9	3.1	5.0	0.6	0.9	2.9	3.2	2.5	2.9
24	0.4	0.20	0.63		1.9	3.0	4.9	0.9	1.1	2.8	3.0	2.3	2.7
25	0.4	0.21	0.63		1.9	3.1	5.0	0.5	0.7	2.6	3.0	1.7	2.2
26	0.4	0.23	0.69		2.0	2.8	4.8	0.6	0.7	2.8	3.1	2.3	2.6
27	0.4	0.19	0.60		2.1	2.8	4.9	0.7	0.9	2.9	3.5	1.9	2.5
28	0.4	0.20	0.67		1.9	3.0	4.9	0.6	0.9	2.7	3.0	2.4	2.7
29	0.4	0.21	0.62		1.9	3.0	4.9	0.6	0.9	2.7	3.0	2.7	3.0
30	0.4	0.20	0.60	0.54	1.9	3.1	5.0	0.6	0.9	2.7	2.9	1.9	2.5
31	0.4	0.22	0.63		1.9	3.3	5.2	0.8	1.1	2.7	3.1	2.8	3.1

Avg.	0.42	0.22	0.66	0.61	1.9	2.9	4.5	0.6	0.9	2.8	3.2	2.4	2.8
Max.	0.50	0.24	0.77	0.65	2.1	3.8	5.8	0.9	1.1	3.1	3.5	3.0	3.5
Min.	0.40	0.19	0.58	0.54	1.3	2.3	0.0	0.4	0.6	2.2	2.9	1.7	2.2

WSSN: 2310

Date	pH (S.U.)		Total Hardness as CaCO3 (mg/L)		Total Alkalinity as CaCO3 (mg/L)		Non-Carbonate Hardness as CaCO3 (mg/L)		Calcium as Ca2+ (mg/L)		Magnesium as Mg2+ (mg/L)		Chloride as Cl- (mg/L)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
1	8.25	7.82	303	204	248	109	55	95	97.8	63.3	14.6	11.7	47	77
2	8.12	8.27	303	193	248	97	55	96	98.6	54.5	14.1	13.6	47	77
3	8.21	8.25	307	192	243	96	64	96	113.8	64.1	5.8	7.8	47	75
4	8.42	7.84	312	193	257	97	55	96	103.4	55.3	13.6	13.6	48	76
5	8.21	8.23	314	197	257	98	57	99	109.0	65.7	9.7	7.8	45	74
6	8.27	8.34	314	210	254	115	60	95	109.8	69.7	9.7	8.3	47	74
7	8.43	8.08	326	203	265	102	61	101	103.4	58.5	16.5	13.6	47	78
8	8.35	8.00	326	197	268	93	58	104	107.4	56.9	14.1	13.1	48	77
9	8.33	7.95	324	200	263	97	61	103	121.0	71.3	6.3	5.8	48	77
10	8.23	7.95	329	190	269	81	60	109	106.6	53.7	15.1	12.6	48	82
11	8.17	7.95	321	190	261	88	60	102	111.4	68.1	10.2	4.9	48	79
12	8.13	8.33	324	197	260	95	64	102	116.2	70.5	8.3	2.9	49	81
13	8.13	7.41	322	208	261	100	61	108	119.4	75.4	6.3	4.9	48	83
14	8.18	8.16	334	206	270	97	64	109	101.0	55.3	20.4	16.5	48	81
15	8.24	8.18	328	207	269	102	59	105	97.0	59.3	19.9	14.1	50	83
16	8.29	8.37	324	200	269	95	55	105	103.4	55.3	16.0	14.6	48	82
17	8.22	8.18	321	201	261	89	60	112	107.4	65.7	12.2	9.2	44	85
18	8.24	8.15	325	203	264	91	61	112	108.2	60.9	13.6	12.2	48	82
19	7.99	8.03	319	199	258	91	61	108	117.0	69.7	6.8	5.8	48	84
20	8.23	7.90	318	196	252	90	66	106	116.2	70.5	7.3	4.9	48	83
21	8.31	8.20	317	173	260	77	57	96	99.4	51.3	17.0	9.7	45	78
22	8.31	8.35	319	177	266	72	53	105	102.6	48.1	15.1	14.1	47	80
23	8.25	8.22	322	168	263	71	59	97	121.0	52.9	15.1	7.8	49	79
24	8.27	8.49	323	179	264	72	59	107	108.2	54.5	12.6	10.2	46	79
25	8.28	8.12	312	183	255	72	57	111	109.0	63.3	10.2	6.3	49	82
26	8.25	8.18	307	182	248	79	59	103	109.0	65.7	9.7	3.9	46	81
27	8.21	8.07	289	173	232	76	57	97	102.6	64.1	8.3	4.9	44	80
28	8.26	8.03	290	174	235	67	55	107	95.4	52.1	13.1	10.7	42	82
29	8.29	7.62	313	184	251	75	62	109	101.0	53.7	15.1	11.7	43	83
30	8.17	7.77	319	197	257	84	62	113	107.4	60.9	12.2	10.7	46	84
31	8.17	7.67	320	181	260	60	60	121	117.8	69.7	7.3	1.9	48	87

Avg.	8.24	8.07	317	192	258	88	59	104	107.8	61.3	12.1	9.3	47	80
Max.	8.43	8.49	334	210	270	115	66	121	121.0	75.4	20.4	16.5	50	87
Min.	7.99	7.41	289	168	232	60	53	95	95.4	48.1	5.8	1.9	42	74

WSSN: 2310

Date	Total Coliform						Standard Plate Count (Simplate MPN)		Conductivity (mS)	Temp. C	Color		Odor	
	Raw (Colilert MPN)		Filter Confluence (N&S)		Plant Tap		Raw	Tap			Raw	Tap	Raw	Tap
	# Samples	Count	# Samples	# pos	# Samples	# pos			Raw	Tap				
1	1		12	0	1	0	> 14760	4	0.38	5.1				
2	1		12	0	1	0	2320	2	0.38	6.4				
3	1		12	0	1	0	1360	4	0.37	5.6				
4	1		12	0	1	0	1020	< 2	0.38	5.4				
5	1		12	0	1	0	340	< 2	0.38	6.1				
6	1		4	0	1	0	40	2	0.40	7.2				
7	1		0	0	1	0	80	< 2	0.38	1.4				
8	1		0	0	1	0	240	< 2	0.38	3.3				
9	1		12	0	1	0	120	< 2	0.40					
10	1		12	0	1	0	240	< 2	0.38	6.5				
11	1		12	0	1	0	120	< 2	0.38	4.9				
12	1		12	0	1	0	< 2	< 2	0.39	6.0				
13	1		12	0	1	0	160	< 2	0.32	6.4				
14	1		12	0	1	0	80	2	0.39	5.6				
15	1		12	0	1	0	40	< 2	0.40	5.9				
16	1		12	0	1	0	> 14760	< 2	0.40	6.0				
17	1		12	0	1	0	166	< 2	0.39	6.3				
18	1		12	0	1	0	161	< 2	0.40	5.8				
19	1		12	0	1	0	116	2	0.39	6.4				
20	1		12	0	1	0	156	< 2	0.35	7.0				
21	1		12	0	1	0	137	< 2	0.36	3.9				
22	1		12	0	1	0	216	< 2	0.36	3.4				
23	1		12	0	1	0	324	< 2	0.35	4.5				
24	1		12	0	1	0	324	< 2	0.36	6.4				
25	1		12	0	1	0	470	< 2	0.37	7.4				
26	1		12	0	1	0	392	< 2	0.36	5.1				
27	1		12	0	1	0	> 738	< 2	0.37	5.6				
28	1		12	0	1	0	9400	2	0.36	4.5				
29	1		12	0	1	0	2640	< 2	0.37	4.0				
30	1		12	0	1	0	560	< 2	0.37	2.2				
31	1		12	0	1	0	300	< 2	0.37	2.6				

Avg.									0.38	5.2				
Max.							9400	4	0.40	7.4				
Min.									0.32	1.4				

Date	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WS	Number of Samples
1									2.8	0.7	2
2	0.2	2.0	1.9	1.8	1.2	0.1	1.2	2.1	1.6	1.8	10
3	0.9	1.7	1.9	1.6	1.0	0.1	1.5	1.8	1.8	2.0	10
4	0.6	1.1	1.6	1.7	0.9	0.1	1.4	1.8	1.3	1.7	10
5											0
6											0
7											0
8									0.4	0.4	2
9	0.9	0.1	1.4	0.2	0.1	0.2	1.7	2.5	0.3	1.2	10
10	0.7	0.2	1.8	1.7	0.2	0.2	1.5	1.9	1.6	0.8	10
11	0.6	0.5		1.4	0.8	0.1	1.5	1.8	1.5	0.9	9
12											0
13											0
14											0
15									0.8	1.6	2
16	0.7	1.7	1.5	1.6	0.7	0.2	0.8	1.8	1.3	2.1	10
17	0.6	0.8	1.4	1.5	0.7	0.1	0.8	1.8	1.1	1.4	10
18	0.8	1.5	1.5	1.5	0.5	0.2	1.5	1.8	1.2	1.3	10
19	0.5	1.7	1.7	1.3	0.8	0.1			0.9	1.0	8
20											0
21											0
22											0
23	0.7	1.5	1.3	1.5	0.8	0.3	1.5	1.8	1.8	0.3	10
24	0.6	1.1	2.1	0.6	0.5	0.5	1.0	2.0	0.7	1.2	10
25											0
26											0
27											0
28											0
29											0
30	0.6	0.4	1.7	1.5	0.8	0.3	1.2	2.0		1.4	9
31											0

Distribution Sample Summary

Total # of routine distribution samples analyzed	132
Total # of routine distribution samples required	100

Distribution Disinfectant Total Residual Summary

Percentage of samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	1.13

Distribution Bacteriological Summary

Total # of positive routine distribution samples	0
Percent of routine distribution samples positive	0%

See page 9 for positive sample information.

Date	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										
	1	2	3	4	5	6	7	8	CS	WS	Number of Samples
1									3.2	1.0	2
2	0.4	2.6	2.5	2.1	1.5	0.2	1.5	2.5	2.1	2.0	10
3	1.2	2.0	2.1	1.9	1.3	0.4	1.8	2.1	2.1	2.3	10
4	1.0	1.4	1.9	2.0	1.3	0.2	1.7	2.1	1.5	1.9	10
5											0
6											0
7											0
8									0.5	0.6	2
9	1.3	0.2	1.6	0.4	0.3	0.4	1.9	2.7	0.5	1.5	10
10	1.1	0.3	2.1	2.0	0.3	0.3	1.7	2.2	1.9	1.1	10
11	1.0	0.5	1.5	2.0	0.8	0.3	2.1	1.9	2.0	2.0	10
12	0.9	0.8		1.6	1.0	0.3	1.7	2.0	1.8	1.2	9
13											0
14											0
15									1.1	1.9	2
16	0.9	2.1	1.8	1.8	1.0	0.3	1.0	2.3	1.5	2.4	10
17	0.8	1.1	1.7	1.8	1.0	0.3	1.0	2.1	1.4	1.8	10
18	1.0	1.7	1.7	1.8	0.8	0.2	1.7	2.0	1.4	1.6	10
19	0.8	1.9	1.9	1.5	1.1	0.3			1.2	1.3	8
20											0
21											0
22											0
23	1.0	1.7	1.6	1.7	1.1	0.5	1.7	2.1	2.0	0.6	10
24	0.8	1.2	2.3	0.8	0.7	0.8	1.2	2.3	0.9	1.4	10
25											0
26											0
27											0
28											0
29											0
30	0.8	0.5	1.9	1.7	1.1	0.5	1.4	2.4		1.6	9
31											0

Distribution Disinfectant Total Residual Summary	
Percent samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	1.4