

**CITY of FLINT WATER TREATMENT PLANT MONTHLY OPERATION REPORT**

**SUPPLY NAME:** CITY of FLINT WATER PLANT  
**WSSN:** 2310

Michael Glasgow  
 Operator-in-Charge

June 2015  
 Month/Year

F-1R, F-2  
 Certification of Operator-in-Charge

F-1  
 Water Plant Classification

  
 Signature of Operator-in-Charge

Genesee  
 County

**Treatment Rate and Filter Data**

Maximum Treatment Rate:	<u>18.5</u>	Million Gallons per Day
Rated Plant Capacity:	<u>36</u>	Million Gallons per Day
Average Filter Run:	<u>90</u>	Hours
Average Head Loss:	<u>n/a</u>	Feet *(filter head loss meters not operational)
Average Filtration Rate:	<u>2.3</u>	Gallons Per Square Feet per Minute
Maximum Filtration Rate:	<u>3.3</u>	Gallons Per Square Feet per Minute
Average Wash Water Use:	<u>2.0%</u>	Percent of Treated Water

**Chemical Data**

Chlorine on hand:	<u>12,000</u> lb.	Est. supply:	<u>13</u> days
Primary Coagulant (Ferric Chloride) on hand:	<u>220,000</u> lb.	Est. supply:	<u>13</u> days
Lime (CaO) on hand:	<u>259</u> tons	Est. supply:	<u>32</u> days
Fluoride on Hand:	<u>18,000</u> lb.	Est. supply:	<u>45</u> days
Cost of All Chemicals per Million Gallons:	<u>n/a</u> dollars		
Total Power Cost per Million Gallons:	<u>n/a</u> dollars		

**Remarks**

	Confluence Point # 1 (N)	Confluence Point # 2 (S)
Number of filter confluence samples > 0.3 NTU:	<u>0</u>	<u>0</u>
Number of filter confluence samples collected:	<u>211</u>	<u>211</u>
Percent of filter confluence samples > 0.3 NTU:	<u>0.0%</u>	<u>0.0%</u>
Number of filter confluence samples > 1 NTU	<u>0</u>	<u>0</u>

**Did any individual filter exceed:**

- 1.0 NTU in two consecutive measurements taken 15 minutes apart? NO  
 If yes, attach specific filter(s) information and indicate required follow-up status.
- 0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation? NO  
 If yes, attach specific filter(s) information and indicate required follow-up status.
- 1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months? NO  
 If yes, attach specific filter(s) information and indicate required follow-up status.
- 2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months? NO  
 If yes, attach specific filter(s) information and indicate required follow-up status.
  
- Was continuous (every 15 minutes) filter monitoring equipment off-line during the month? NO  
 If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.
  
- Did POE disinfectant residual fall below 0.2 ppm during the month? NO  
 If yes, indicate date(s) and duration on a separate sheet.
  
- Was minimum C\*T credit achieved for the entire month? YES  
 If no, indicate on a separate sheet the date(s) not achieved.
  
- Was continuous POE chlorine residual monitoring equipment off-line during the month? NO  
 If yes, indicate date(s) and duration on a separate sheet.



WSSN: 2310

Date	Turbidity, Units												
	Confluence Point. No.1 (N) North						Confluence Point. No.2 (S) South						Point of Entry
	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	Number of Samples	Avg.	Max	No. of 4 Hr. Compliance periods	No. of 4 Hr. Compliance periods >0.3 NTU	No. of Samples >0.3 NTU	Plant Tap NTU
1	7	0.10	0.13	6	0	0	7	0.09	0.09	6	0	0	0.09
2	8	0.07	0.09	6	0	0	8	0.07	0.08	6	0	0	0.07
3	7	0.09	0.11	6	0	0	7	0.08	0.12	6	0	0	0.09
4	6	0.09	0.11	6	0	0	6	0.08	0.09	6	0	0	0.09
5	7	0.09	0.10	6	0	0	7	0.08	0.09	6	0	0	0.09
6	8	0.08	0.10	6	0	0	8	0.07	0.08	6	0	0	0.08
7	7	0.07	0.08	6	0	0	7	0.07	0.10	6	0	0	0.09
8	8	0.09	0.13	6	0	0	8	0.06	0.08	6	0	0	0.08
9	6	0.09	0.15	6	0	0	7	0.08	0.09	6	0	0	0.07
10	7	0.13	0.23	6	0	0	7	0.07	0.11	6	0	0	0.09
11	7	0.08	0.14	6	0	0	7	0.07	0.10	6	0	0	0.12
12	7	0.08	0.10	6	0	0	7	0.08	0.09	6	0	0	0.08
13	7	0.08	0.11	6	0	0	7	0.08	0.10	6	0	0	0.09
14	8	0.09	0.16	6	0	0	8	0.08	0.10	6	0	0	0.09
15	7	0.08	0.09	6	0	0	7	0.07	0.08	6	0	0	0.08
16	7	0.07	0.11	6	0	0	7	0.08	0.13	6	0	0	0.08
17	7	0.07	0.10	6	0	0	7	0.06	0.07	6	0	0	0.07
18	6	0.08	0.10	6	0	0	6	0.08	0.09	6	0	0	0.07
19	6	0.07	0.08	5	0	0	6	0.06	0.07	5	0	0	0.09
20	8	0.08	0.09	6	0	0	8	0.08	0.11	6	0	0	0.09
21	7	0.09	0.10	6	0	0	7	0.09	0.11	6	0	0	0.10
22	7	0.07	0.09	6	0	0	7	0.08	0.11	6	0	0	0.09
23	7	0.07	0.10	6	0	0	7	0.06	0.08	6	0	0	0.08
24	7	0.09	0.11	6	0	0	7	0.08	0.12	6	0	0	0.08
25	7	0.09	0.10	6	0	0	7	0.08	0.09	6	0	0	0.09
26	6	0.11	0.15	5	0	0	6	0.08	0.10	5	0	0	0.09
27	7	0.10	0.14	6	0	0	7	0.09	0.12	6	0	0	0.10
28	7	0.13	0.17	6	0	0	7	0.09	0.11	6	0	0	0.12
29	7	0.10	0.12	6	0	0	7	0.09	0.10	6	0	0	0.10
30	7	0.12	0.15	6	0	0	7	0.10	0.13	6	0	0	0.09
Avg.	7	0.09	0.12	6	0	0	7	0.08	0.10	6	0	0	
Max.	8	0.13	0.23	6	0	0	8	0.10	0.13	6	0	0	0.12
Min.	6	0.07	0.08	5	0	0	6	0.06	0.07	5	0	0	

Date	Fluoride Applied as F- mg/L	Fluoride Analysis (mg/L)			Chlorine Application (mg/L)			Chlorine Residual (mg/L)					
					Intermediate Chlorine	Post Chlorine	Total Chlorine	Filtered		3 MG Well		Tap	
		Raw	Tap	Dist.				Free	Total	Free	Total	Free	Total
1	0.6	0.20	0.73		2.8	2.6	5.4	0.4	0.7	1.6	1.9	1.4	1.8
2	0.6	0.19	0.81		2.7	2.3	5.0	0.5	0.8	1.7	2.0	1.7	1.9
3	0.6	0.20	0.79		2.7	2.5	5.2	0.4	0.5	1.7	2.0	1.7	2.0
4	0.6	0.20	0.82	0.76	2.8	2.1	4.9	0.5	0.7	1.8	2.0	1.7	1.9
5	0.6	0.20	0.82		2.6	2.2	4.8	0.6	0.8	1.9	2.2	1.4	1.7
6	0.6	0.20	0.74		2.5	2.2	4.7	0.4	0.6	1.9	2.2	1.8	2.1
7	0.6	0.20	0.76		2.1	2.1	4.2	0.3	0.6	1.8	2.1	1.7	1.9
8	0.6	0.19	0.78		2.2	2.3	4.5	0.4	0.5	1.9	2.1	1.8	2.1
9	0.6	0.20	0.70		2.7	2.7	5.4	0.5	0.7	1.6	1.8	1.6	1.8
10	0.6	0.20	0.74	0.70	2.6	2.6	5.2	0.4	0.5	1.9	2.1	1.5	1.8
11	0.6	0.20	0.75		2.6	2.7	5.3	0.3	0.5	1.5	1.7	1.5	1.7
12	0.6	0.20	0.72		2.6	2.6	5.2	0.5	0.8	1.7	2.1	1.6	1.9
13	0.6	0.20	0.70		2.7	2.4	5.1	0.3	0.5	1.7	2.0	1.7	2.0
14	0.6	0.19	0.69		2.8	2.7	5.5	0.3	0.4	1.7	1.9	1.7	1.9
15	0.6	0.20	0.72		2.9	2.8	5.7	0.3	0.5	1.8	2.1	1.7	1.9
16	0.6	0.20	0.80		2.5	2.2	4.7	0.3	0.5	1.8	2.0	1.8	2.0
17	0.5	0.19	0.70		2.9	2.3	5.2	0.5	0.7	1.8	2.0	1.7	2.0
18	0.5	0.20	0.70	0.72	2.8	2.8	5.6	0.4	0.5	1.9	2.3	1.9	2.3
19	0.6	0.20	0.74		2.6	2.5	5.1	0.5	0.7	1.8	2.2	0.7	0.9
20	0.5	0.19	0.71		3.0	2.6	5.6	0.3	0.5	1.7	1.9	1.7	1.9
21	0.6	0.19	0.72		3.1	2.9	6.0	0.3	0.5	1.8	2.1	1.7	2.0
22	0.6	0.19	0.70		3.4	2.6	6.0	0.4	0.7	1.9	2.2	0.7	0.9
23	0.6	0.19	0.81		3.6	2.9	6.5	0.4	0.7	1.7	1.9	1.7	1.9
24	0.6	0.20	0.82		3.4	2.6	6.0	0.5	0.7	1.7	2.0	1.5	1.8
25	0.6	0.19	0.73		3.3	2.5	5.8	0.3	0.5	1.5	1.7	0.5	0.8
26	0.6	0.19	0.72		3.2	3.5	6.7	0.6	0.8	2.5	2.8	2.0	2.2
27	0.5	0.18	0.71		3.1	3.2	6.3	0.5	0.7	2.7	3.0	0.6	0.9
28	0.5	0.18	0.65		3.2	3.6	6.8	0.3	0.5	1.8	2.1	1.7	2.0
29	0.5	0.19	0.70		3.3	3.2	6.5	0.4	0.7	2.4	2.8	2.3	2.6
30	0.5	0.19	0.71		3.2	3.5	6.7	0.3	0.6	1.8	2.1	1.8	2.1
Avg.	0.58	0.19	0.74	0.73	2.9	2.7	5.5	0.4	0.6	1.8	2.1	1.6	1.8
Max.	0.60	0.20	0.82	0.76	3.6	3.6	6.8	0.6	0.8	2.7	3.0	2.3	2.6
Min.	0.50	0.18	0.65	0.70	2.1	2.1	4.2	0.3	0.4	1.5	1.7	0.5	0.8

WSSN: 2310

Date	pH (S.U.)		Total Hardness as CaCO <sub>3</sub> (mg/L)		Total Alkalinity as CaCO <sub>3</sub> (mg/L)		Non-Carbonate Hardness as CaCO <sub>3</sub> (mg/L)		Calcium as Ca <sup>2+</sup> (mg/L)		Magnesium as Mg <sup>2+</sup> (mg/L)		Chloride as Cl <sup>-</sup> (mg/L)	
	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap	Raw	Tap
1	8.18	7.64	272	180	226	76	46	104	86.6	63.3	13.6	5.3	48	88
2	7.97	7.56	271	177	216	61	55	116	93.0	60.9	10.2	7.8	46	92
3	7.97	7.60	274	178	222	74	52	104	82.6	61.7	16.5	5.8	49	90
4	7.89	7.70	274	160	222	54	52	106	84.2	57.7	15.6	3.9	47	93
5	7.88	7.55	274	190	222	76	52	114	81.0	64.1	17.5	7.3	49	94
6	7.89	7.69	277	176	221	66	56	110	94.6	60.9	10.2	5.8	44	89
7	7.96	7.75	275	185	224	72	51	113	93.8	64.9	9.7	6.3	48	92
8	7.90	7.67	280	185	224	73	56	112	96.2	68.9	9.7	4.4	46	92
9	7.94	7.67	272	164	224	54	48	110	76.2	56.9	19.9	5.3	50	95
10	7.94	7.60	278	148	226	40	52	108	78.6	52.1	19.4	4.4	50	94
11	7.94	7.55	276	172	228	66	48	106	80.2	63.3	18.5	3.4	49	94
12	8.11	7.75	278	190	228	86	50	104	82.6	68.1	17.5	4.9	49	93
13	8.01	7.75	278	197	225	89	53	108	97.8	75.4	8.7	2.9	46	92
14	7.88	7.67	277	196	225	89	52	107	93.0	68.9	11.2	6.3	48	89
15	7.99	7.76	276	206	226	94	50	112	94.6	74.5	9.7	4.9	48	95
16	8.02	7.65	272	194	224	76	48	118	92.2	68.1	12.6	5.3	46	100
17	7.95	7.72	264	202	224	90	40	112	91.4	77.0	8.7	2.4	48	93
18	7.90	7.58	270	174	222	62	48	112	80.2	59.3	17.9	6.3	49	96
19	7.92	7.49	276	182	226	72	50	110	80.2	67.3	18.5	3.4	48	97
20	7.95	7.71	279	193	229	101	50	92	94.6	71.3	11.7	2.9	46	82
21	7.92	7.51	280	173	228	75	52	98	92.2	67.3	12.6	2.9	47	84
22	8.03	7.57	274	176	236	74	38	102	94.6	64.9	9.2	3.4	45	86
23	7.98	7.40	274	210	236	112	38	98	89.0	82.6	12.6	0.9	48	93
24	7.98	7.43	278	214	236	128	42	86	81.8	72.1	17.9	8.3	50	97
25	7.97	7.48	274	194	226	94	48	100	83.4	74.5	15.4	1.9	48	91
26	7.90	7.55	278	200	228	100	50	100	79.4	75.4	21.9	2.9	48	93
27	7.96	7.56	282	186	238	78	44	108	92.2	76.2	12.6	2.9	46	89
28	7.97	7.56	276	164	230	62	46	102	85.0	56.9	15.6	5.3	46	89
29	7.97	7.70	276	167	228	59	48	108	86.6	57.7	14.6	7.3	45	89
30	8.32	7.56	258	160	212	60	46	100	83.4	44.9	12.2	11.7	47	86

Avg.	7.97	7.61	275	183	226	77	49	106	87.4	65.9	14.1	4.9	47	92
Max.	8.32	7.76	282	214	238	128	56	118	97.8	82.6	21.9	11.7	50	100
Min.	7.88	7.40	258	148	212	40	38	86	76.2	44.9	8.7	0.9	44	82

Date	Total Coliform						Standard Plate Count (Simplate MPN)		Conductivity (mS)	Temp. C	Color		Odor	
	Raw (Colilert MPN)		Filter Confluence (N&S)		Plant Tap		Raw	Tap			Raw	Tap	Raw	Tap
	# Samples	Count	# Samples	# pos	# Samples	# pos	Raw	Tap	Tap	Raw	Raw	Tap	Raw	Tap
1	1	2098	12	0	1	0	970	< 2	0.50	18.8				
2	1	295	12	0	1	0	280	< 2	0.50	18.5				
3	1	171	12	0	1	0	230	< 2	0.50	18.8				
4	1	262	12	0	1	0	230	< 2	0.47	18.8				
5	1	768	12	0	1	0	450	< 2	0.51	19.1				
6	1	262	12	0	1	0	300	< 2	0.48	18.7				
7	1	134	12	0	1	0	480	< 2	0.50	18.7				
8	1	98	12	0	1	0	350	< 2	0.50	19.4				
9	1	1733	12	0	1	0	623	< 2	0.47	19.5				
10	1	195	12	0	1	0	280	< 2	0.45	19.9				
11	1	175	12	0	1	0	230	< 2	0.49	20.0				
12	1	546	12	0	1	0	770	< 2	0.52	21.5				
13	1	426	12	0	1	0	260	< 2	0.54	20.5				
14	1	5172	12	0	1	0	800	2	0.52	20.3				
15	1	733	12	0	1	0	260	< 2	0.54	20.5				
16	1	512	12	0	1	0	260	< 2	0.52	21.0				
17	1	404	12	0	1	0	300	< 2	0.54	22.2				
18	1	228	12	0	1	0	1120	< 2	0.50	20.5				
19	1	2247	10	0	1	0	4400	< 2	0.52	21.2				
20	1	326	12	0	1	0	> 738	< 2	0.51	20.9				
21	1	265	12	0	1	0	2160	< 2	0.50	20.6				
22	1	683	12	0	1	0	1770	< 2	0.50	20.9				
23	1	2098	12	0	1	0	1660	< 2	0.56	20.9				
24	1	960	12	0	1	0	1120	< 2	0.60	20.8				
25	1	455	12	0	1	0	1120	< 2	0.54	21.1				
26	1	1246	10	0	1	0	3550	< 2	0.53	20.9				
27	1	395	12	0	1	0	450	< 2	0.49	20.3				
28	1	495	12	0	1	0	450	< 2	0.47	20.5				
29	1	428	12	0	1	0	450	< 2	0.46	20.8				
30	1	4884	12	0	1	0	2760	< 2	0.48	21.9				

Avg.									0.51	20.3				
Max.		5172					4400	< 2	0.60	22.2				
Min.									0.45	18.5				

Date	Free Chlorine Residual at Bacteriological Monitoring Stations mg/l										Number of Samples
	1	2	3	4	5	6	7	8	CS	WS	
1											0
2											0
3	0.1	1.0	1.2	0.7	0.3	0.2	0.5	1.0	1.0	1.0	10
4	0.7	0.7	1.0	0.1	0.3	0.4	0.5	1.1	0.1	1.2	10
5											0
6											0
7											0
8											0
9	0.7	0.5	1.0	0.7	0.3	0.3	0.6	1.1	0.2	1.1	10
10	0.1	1.0	1.0	0.7	0.2	0.2	0.4	1.0	0.1	0.8	10
11	0.2	0.7	0.7	0.5	0.2	0.1	0.4	0.9	0.8	0.1	10
12											0
13											0
14											0
15											0
16											0
17	0.1	0.7	1.1	0.8	0.3	0.1	0.2	1.1	0.5	1.2	10
18	0.6	0.9	1.1	0.7	0.2	0.2	0.3	1.0	1.0	1.2	10
19											0
20											0
21											0
22											0
23	0.4	0.7	0.7	0.4	0.3				0.1	0.5	7
24	0.5	0.8	0.8	0.4	0.2	0.2	0.3	0.9	0.1	1.3	10
25						0.3	0.5	0.9	0.5		4
26											0
27											0
28											0
29											0
30	0.7	0.8	1.0	0.5	0.3	0.3	0.7	1.3	0.5	0.9	10

Distribution Sample Summary

Total # of routine distribution samples analyzed	101
Total # of routine distribution samples required	100

Distribution Disinfectant Total Residual Summary

Percentage of samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	0.60

Distribution Bacteriological Summary

Total # of positive routine distribution samples	1
Percent of routine distribution samples positive	1%

See page 9 for positive sample information.

Date	Total Chlorine Residual at Bacteriological Monitoring Stations mg/l										Number of Samples
	1	2	3	4	5	6	7	8	CS	WS	
1											0
2											0
3	0.3	1.2	1.5	1.0	0.5	0.4	0.8	1.2	1.2	1.2	10
4	1.0	1.0	1.3	0.2	0.5	0.5	0.8	1.3	0.2	1.5	10
5											0
6											0
7											0
8											0
9	1.0	0.8	1.3	1.0	0.4	0.5	0.9	1.3	0.3	1.4	10
10	0.1	1.3	1.3	1.0	0.5	0.4	0.6	1.2	0.2	1.0	10
11	0.3	1.0	1.0	0.8	0.4	0.2	0.7	1.1	1.0	0.2	10
12											0
13											0
14											0
15											0
16											0
17	0.2	1.1	1.3	1.1	0.6	0.4	0.5	1.5	0.8	1.5	10
18	0.9	1.2	1.3	1.0	0.5	0.5	0.5	1.4	1.2	1.5	10
19											0
20											0
21											0
22											0
23	0.6	1.0	1.0	0.7	0.5				0.1	0.8	7
24	0.7	1.1	1.1	0.6	0.4	0.4	0.5	1.2	0.2	1.5	10
25						0.4	0.7	1.2	0.7		4
26											0
27											0
28											0
29											0
30	1.0	1.2	1.3	0.7	0.5	0.5	1.0	1.6	0.8	1.1	10

Distribution Disinfectant Total Residual Summary	
Percent samples with a detectable disinfectant residual	100%
Average disinfectant residual this month	0.8



